



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 234

Dated: 06/04/2023

FIRE SAFETY CERTIFICATE

Certified that the The Mankaur International School located at Plot No. 21 & 22, Gali No.09, 7/21 & 7/22, Near Police Station, Swaroop Nagar, Delhi-110084 comprised of basement, ground & first floors but school is running at ground & first floor only owned/occupied by the The Mankaur International School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 18.03.2023 in the presence of Mr. Praven Kumar (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class 'Group B Educational' for ground & first floor only with effect from06/04/2023. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...06/04/2023..... at New Delhi


 (Atul Garg)
 Director
 Ph:-011-23414000
 of/ep

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, The Mankaur International School located at Plot No. 21 & 22, Gali No.09, 7/21 & 7/22, Near Police Station, Swaroop Nagar, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : The Mankaur International School at Plot No. 21 & 22, Gali No.09, 7/21 & 7/22, Near Police Station, Swaroop Nagar, Delhi-110042.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Composition of building : Basement, Ground & First Floor **but school is running at ground & first floor only**, basement sealed by brick walls
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 18.03.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Praveen Kumar (Manager)
10. Year of Construction : 2009
11. Applicant's letter No. : Letter No. Nil dated 02.03.2023

Plot Area-659Sqm Covered Area- 437Sqm

Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
Access to building			
• Road width	06m	06m	MR
• Gate width	4.5m	4.5m	MR
• Width of internal road	NA	NA	NA
Number, Width, Type & Arrangement of Exits			
a. Number of staircases	NA	NA	NA
• Upper Floors	NA	NA	NA
• Basements	NA	NA	NA
b. Width of staircases	1.5m each	1.5m x2	MR
• Upper Floors	NA	NA	NA
• Basements	NA	NA	NA
c. Protection of exits	NA	NA	NA
• Fire check door	NA	NA	NA
• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	01m	01m	MR
f. Door Size	NA	NA	NA
Compartmentation.			
• Fire check door	NA	NA	NA
• Sealing of electrical shafts	NA	NA	NA
• Fire Rating of shaft door	NA	NA	NA
• Water Curtain	NA	NA	NA
• Fire Dampers	NA	NA	NA
Smoke Management System.			
• Basements	12 a/c per hour	Sealed by brick wall	NA
• Upper floors	12 a/c per hour	Natural Ventilation	MR
Fire Extinguishers			
• Total numbers	06nos	06nos	MR

	<ul style="list-style-type: none"> Types ISI marking 	ABC/Co2	ABC-06	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate


~~DO/NW~~
 EJP
 23/03/2023
 S/o D. P. Shukla

27/3/2023

CFO
 28/3/2023

Director
 29/03/23

ADYKT


 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN