



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022/WZ/College/ 12

Dated 06/04/2023

FIRE SAFETY CERTIFICATE

Certified that the National Institute of Labour Economics Research and Development located at Plot No. 25, Sector A-7, Institutional Area, Narela, Delhi-110040 comprised of Two Blocks-Seminar Block (Ground+One upper floor) and Academic Block (Ground+Two upper floors) owned/ occupied by National Institute of Labour Economics Research and Development have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 24.03.2023 in the presence of Sh. J.S. Chauhan (Asst. Director) and found that the building/ premises is fit for occupancy Mixed 'Assembly & Business' with effect from 06/04/2023 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/2023.. at New Delhi by

(Atul Garg)
Director

Ph-011-23414000

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : National Institute of Labour Economics Research and Development
Plot No. 25, Sector-7A, Narcla, Delhi-110040.
2. Type of Occupancy : Institutional
3. Building comprised : Seminar Block- (Gr.+One upper floor) , Academic Block-(Gr.+02 upper Floors)
4. Type of Case : New Case
5. Details of Previous NOC : NIL
6. Fire Safety directives letter No : F6/MS/DFS/BP/99/2569 Dated:15/01/1999
& F6/MS/DFS/2003/705 Dated: 02/04/2003
7. Date of inspection : 24.03.2023
8. Name of Inspecting Officer : ADO (BW)
9. Name and designation of officers
From the building side : Sh. J.S Chauhan (Asst. Director)
10. Year of Construction : -----
11. Applicant's letter No. : 23(1)/General/D.V.M-51/2022-23/228 Dated-14/02/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Directives letter no. F6/MS/DFS/BP/99/2569	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	6 m	MR
	• Gate width	5 m	5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Seminar Block- 01 Academic Block- 03	01 03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m in each block	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	Required in Academic Block	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	Required	Provided	MR
	• Types	Water/ Co2/ ABC	Provided	MR
	• IS marking	Yes	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	40m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/Heat	Provided	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power 	G.F.	Provided	MR
		NA	NA	NA
		Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	25	27	MR
		Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2400 lpm	Provided	MR
		70 m	Provided	MR
		01	Provided	MR
		450 lpm	Provided	MR
		70 m	Provided	MR
		2400 lpm	Provided	MR
		70 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	3,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		2500-5000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Note- Half portion of Academic Block found converted into Girls Hostel.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/2022/WZ/College/39 dated 02/08/2023.

In view of the substantial compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules it is recommended to Grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules,2010.

(Signature)
ADO (BW)
27/3/23

Signature of Inspecting Officer
Name:- Rajeev Kumar Sinha
Designation:- ADO/BW

DO/WZ

(Signature)
28/03/2023

FO (D.P. Bhardwaj)

(Signature)
27/4/2023

CFD
(Signature)
3/4/2023

Director
(Signature)
3/4/23

ADU/BW F+ letter in reply for special
(Signature)
ADO (BW)
05/4/23

Director (DF)
(Signature)
3/4/23

(Signature)