



No. F6/DFS/MS/WZ/ BNQT/2023/ 17

Dated: 18/04/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Grand Utsav Banquet Hall running at Ground Floor only in a building comprised of ground plus three upper floors located at Shop No.- 1, 2, 3 & 4, G.F, MCD Complex, Rani Bagh, Delhi- 110034, owned / occupied by M/s. Grand Utsav Banquet, was inspected by the officer concerned of this department on 12/04/2023 in presence of Shri Hind Pal (Owner) and found that the management have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly - Group D (Ground Floor only)** with effect from 18/04/2023 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 18/04/2023 at New Delhi.

(Ajul Garg)
Director

Copy to: -

1. Sh. Hind Pal, M/s. Grand Utsav Banquet Hall, Shop No.- 1, 2, 3 & 4, G.F, MCD Complex, Rani Bagh, Delhi- 110034.
2. The Deputy Health Officer, Keshav Puram Zone, Municipal Corporation of Delhi, Public Health Department, Keshav Puram, New Delhi.

N/7

INSPECTION REPORT

1. Name & address of the building: M/s. Grand Utsav Banquet located at Shop No.- 1, 2, 3 & 4, G.F, MCD Complex, Rani Bagh, Pitampura, New Delhi- 34.
2. Type of Occupancy : Banquet (Assembly)
3. Type of Case : New Case ✓
4. Details of previous NOC : N/A
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2023/64 dated 27/03/2018
6. Date of inspection : 12.04.2023
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO (West)
8. Name and designation of Officer from the building side : Sh. Hind Pal (Owner/Occupier)
9. Year of Construction : 2017 (as uploaded on MHA Portal)
10. Applicant's letter no. : MHA portal ID 2023022102431

The banquet hall is running at Ground Floor only in a building comprised of ground plus three upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per NBC-IV/ UBBL- 2016	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	Banquet running at GF only	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	Banquet running at GF only	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.0 mts x 02	Provided	MR
3.	Compartmentation			
	• Fire check door	Required in store	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	16	Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

A ~ ~ ~

6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR


Refuge Area			
> Total area	NA	NA	NA
> Location	NA	NA	NA
19	Fire control room		
> Detector system panel	NA	NA	NA
> Flow Switch Panel	NA	NA	NA
> PA System Panel	NA	NA	NA
> Battery backup	NA	NA	NA
> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;		
	NA	NA	NA

The fire protection systems provided in the building were randomly test checked at the time of inspection and found functional.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.


DFA is put up for approval & signature please.

11/00/22
13/04/23


17/4/2023

Signature of the Inspecting Officer
M.K. Chattopadhyay
DO (West Division)



17/4/2023



17/4/2023


H M



F.T. letter is put up for Sign. please


18/4/23


18/4/23