



FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

631

7/5
आजादी का
अमृत महोत्सव

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/NDZ/2023/EH/125

Dated: 13/04/2023

FIRE SAFETY CERTIFICATE

Certified that The Platinum Lounge Restaurant running at shop no. G-17, ground floor of Star City Mall, Plot No. 01-A, Distt Centre, Mayur Vihar-1, Delhi building comprised of basement, ground floor & two upper floors, owned / occupied by Platinum Lounge Restaurant (A unit of True Blue Resto Bar Pvt. Ltd.), was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2020/NDZ/30 Dated 28/01/2020. The premises was re-inspected by the officer concerned of this department on 31/03/2023 in the presence of Sh. Dharambir Singh and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) (Restaurant) with effect from 13/04/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on13/04/2023..... at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to :-

1. Joint Commissioner of Police (Lic.) P. S. : Defence Colony, New Delhi-110024 w.r.t. MHA portal ID-2023031303531 dated 15/03/2023.
2. Authorized Signatory, The Platinum Lounge Restaurant, shop no. G-17, ground floor of Star City Mall, Plot No. 01-A, Distt Centre, Mayur Vihar-1, Delhi.

Conditions for the validity of Fire Safety Certificate:-

1. Fire Safety Certificate is valid for Ground Floor only.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. The trained fire- fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

N/13

1. Name & address of the building : Platinum Lounge Restaurant at G-17, Star City Mall, Plot No. 01-A, Distt Centre, Mayur Vihar-1, Delhi.
2. Building is comprised of : Basement, Ground & 2nd Floor only (Restaurant at Ground Floor only)
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2020/NDZ/30 Dated 28/01/2020
6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/1969 dated 30/08/2004
7. Date of inspection : 31/03/2023
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O. East)
9. Name and designation of Officer from the building side : Mr. Dharambir Singh
10. Year of Construction : 2004
11. Applicant's MHA Portal No. : 2023031303531 dated 15/03/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	13 mtr	MR ✓
	• Gate width	4.5 m	6 m	MR ✓
	• Width of internal road	6 m	6 m	MR ✓
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	2.5 m	2.5 m	MR ✓
	f. Door Size	2.00 m	2.00 m x 2	MR ✓
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Seamed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	2	4	MR ✓
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR




6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR ✓
	• Length of hose reel hose	30 mtr.	30 mtr.	MR ✓
	• Nozzle diameter	5mm.	5mm.	MR ✓
7.	Automatic fire detection and alarming system			
	• Type of detector	Heat	Provided	MR (Old Case)
	• Location of Main Panel	Control Room in Basement	Provided	MR
	• Location of Repeater Panel	Security Room	Provided	MR
	• Alternate source of power	Battery / DG Set	Provided	MR
	• Hooters' Location	Different Location	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR ✓
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	1	NA
	• Hose Box	NA	1	NA
13.	Pumping Arrangements	(All the pump are mounted on terrace)		
	• Terrace Level			
	• Discharge of main pump	4500 LPM	4500 LPM	MR ✓
	➤ Head of main pump	50 m	50 m	MR ✓
	➤ Number of main pumps	2	2	MR ✓
	➤ Jockey pump out put	450 LPM	450 LPM	MR ✓
	➤ Jockey pump head	50 m	50 m	MR
	➤ Standby Pump out put	4500 LPM	4500 LPM	MR
	➤ Standby Pump Head	50 m	50 m	MR ✓
	➤ Auto Staring/Manual stopping	Required	Provided	MR ✓
	➤ Pump House Access	Required	Provided	MR ✓
	• Ground level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltr	2,00,000 ltr	MR ✓
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 ltr	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	HT & LT Panel protected with local CO2 applications	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2020/NDZ/30 Dated 28/01/2020 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
03/04/23

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : D.O. (East)

[Signature]
DCAO/MS

[Signature]
06/04/23

C.F.P.

[Signature]
10/04/2023

Director

[Signature]
11/04/23

[Signature]
DCAO/MS

[Signature]
12/04/23

[Signature]
DO (ED)

D.T.O.