

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2023/School/WZ/ 271

Dated: 18/04/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Heritage School, Main Kanjhawala Road, Opp. Sector-22, Rohini, Delhi-110085**, comprised of **02 Blocks, B + Gr. + 3 & Gr.+ 3 upper floor** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2019/School/WZ/880** dated **23.04.2019**. The premises was re-inspected by the officer concerned of this department on **12.04.2023** in the presence of **Smt. Vibha Gupta (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from 18/04/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 18/04/2023 at New Delhi by

(Atul Darg)  
DIRECTOR

Ph: 011-23414000

Copy to :-

1. The Principal, Delhi Heritage School, Main Kanjhawala Road, Opp. Sector-22, Rohini, Delhi-110085.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

**Conditions for the validity of fire safety certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



12/24

**INSPECTION REPORT**

1. Name & address of the building : Delhi Heritage School, Main Kanjhawala Road, Opp. Sector-22, Rohini, Delhi-110085.
2. Type of Occupancy : Educational (02 Blocks, B + Gr. + 3 & Gr.+ 3 upper floor)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2019/School/WZ/880 dated 23.04.2019
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 12.04.2023
7. Name of Inspecting Officer : Rajeev Kumar Sinha ADO (Bawana)
8. Name and designation of officers  
From the building side : 2004
9. Year of Construction : Smt. Vibha Gupta (Principal)
10. Applicant's letter No. : Online e-mail dated 07.03.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	g. Number of staircases			
	• Upper Floors	A-Block-02 B-Block-02	A-Block-02 B-Block-02	MR
	• Basements	A-Block-02	A-Block-02	MR
	h. Width of staircases			
	• Upper Floor	1.5m	A-Block-1.65 & 0.91m B-Block-1.22 & 1.50m	MR (old case)
	• Basements	A-Block-1.5m	1.5m & 1.2m	MR (old case)
	i. Protection of exits			
	Fire check door			
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	Exhaust fan	MR ✓
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	19nos.	20nos.	MR
	• Types	ABC/CO2	ABC-20	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR ✓
	• Nozzle diameter	5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

*[Handwritten signature]*

*[Handwritten mark]*



N/25

	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm	Provided	MR
		01 each block	Provided	MR
		01 each block	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	01	Provided	MR
		01	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	900lpm & 450lpm	900lpm & 450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		A-Block-15,000ltr B-Block-10,000ltr	A-Block-15,000ltr B-Block-10,000ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> </ul>	NA	NA	NA
		NA	NA	NA

N ✓ ✓ ✓

NA  
NA  
NA

- PA System Panel
- Battery backup
- Building Floor Plans

NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA

20. **Special Fire Protection System for Protection of special Risks, if any:**

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 196 dated 28.04.2022, the FSC issued vide letter no. F.6/DFS/MS/2019/School/WZ/880 dated 23.04.2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*[Handwritten Signature]*  
12/4/23

Signature of the Inspecting Officer  
Name Rajeev Kumar Sinha  
Designation ADO(Bawana)

~~DO (NW)~~

*[Handwritten Signature]*  
15/4

~~DO (DPA)~~  
*[Handwritten Signature]*  
17/4/2023

~~CFO~~  
*[Handwritten Signature]*  
17/4/2023

~~Director~~  
*[Handwritten Signature]*  
17/4/23

*[Handwritten Signature]*  
ADWAM  
Sir: For letter in propk sc

~~Director~~  
*[Handwritten Signature]*  
18/04/23

*[Handwritten Signature]*  
ADW  
18/4