

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 267

Dated: 17/04/2023

FIRE SAFETY CERTIFICATE

Certified that Certified that **Radha Devi Public School, V-1/31, Shukra Bazaar Road, Ph-I, Budh Vihar, Delhi-110041**, comprised of **Ground + Two upper floor** owned/occupied by **Radha Devi Public School** was issued fire safety certificate by this department vide letter no **F.6/DFS/MS/School/WZ/2020/56 dated 12.02.2020**. The premises was re-inspected by the officer concerned of this department on **14.03.2023** in the presence of **Mr. Jatin Garg (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**B**" **Educational Buildings** with effect from **17/04/2023**.....for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 17/04/2023 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, Radha Devi Public School, V-1/31, Shukra Bazaar Road, Ph-I, Budh Vihar, Delhi-110041
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Radha Devi Public School, V-1/31, Shukra Bazaar Road, Phase-I, Budh Vihar, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Gr.+ Two upper floors) ✓
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2020/56 dated 12.02.2020.
5. Fire Safety directives letter No : Director of Education Cir. / NBC Part-IV
6. Date of inspection : 14.03.2023
7. Name of Inspecting Officer : A. K. Sharma ADO (Rohini)
8. Name and designation of officers
From the building side : Mr. Jatin Garg (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : O.D. No. 10688 dated 31.01.2023

Plot area:300 sq yard covered Area-700 Sq yard,

No. of class rooms-20


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular/NBC Part IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 06 mtr Accessible NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floors Basements 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> M.R NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	<ul style="list-style-type: none"> 1.50 mtr NA 	<ul style="list-style-type: none"> 1.18 & 1.00 mtr NA 	<ul style="list-style-type: none"> M.R(Old case) NA
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 mtr	0.90 mtr	M.R(Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<ul style="list-style-type: none"> 6 No's ABC/CO2 ISI Marked 	<ul style="list-style-type: none"> 07 No's ABC Yes 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<ul style="list-style-type: none"> 01 30 m 5 mm 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 		NA	NA
			NA	NA
			NA	NA
8.	MOEFA	Required	Provided	MR ✓
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants	Required	Provided	MR ✓
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	450 & 180 LPM Provided	MR
		40 m	40 m	MR ✓
		Required	Provided	MR
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltr	Provided	M.R.(Old case)
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
-----	---	----	----	----

The fire protection systems provided in the building were tested, checked at random and found some shortcomings.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2020/56 dated 12.02.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Rohini)

~~DO (AW)~~


~~Ajy
15/03/2023
CFO (D.P. Bhandari)~~

~~16/5/2023~~

~~CFO
16/3/2022~~

~~Director
17/03/22~~

Copy sent for F.T letter is put up for sign please.


 ADO (Rohini)
 12/4/23

~~Director (Rohini)
19/4/22~~