

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/ 134

Dated. 27/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name and Style of **M/s Fujiya Restaurant** located at Ground floor, 12/48, Malcha Marg, Chankyapuri, New Delhi-110021 in the building comprised of Ground plus One upper floors was issued FSC by this department vide letter No. F.6/DFS/MS/EH/SZ/2020/SZ/77 dated 19/03/2020. The premise was re-inspected by the officer concerned of this department on 17/04/2023 in the presence of Sh. Surinder Pal of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Assembly, Group-D" (Restaurant at Ground floor only)** with effect from 27/04/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/04/2023 at New Delhi by


A.P. GARG
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Delhi Municipal Corporation, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2023032504257 dated 31.03.2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."


27/04/23

INSPECTION REPORT

1	Name & Address of the Building	M/s Fujiya Restaurant, 12/48, Malcha Marg, Chankyapuri New Delhi-110021		
2	Building Comprised of	G+01 upper floors but Restaurant running at ground floor only).		
3	Type of Occupancy	Assembly, "Group-D" Eating House		
4	Type of Case	Renewal ✓		
5	Details of Previous NOC	F.6/DFS/MS/EH/SZ/2020/SZ/77 dated 19/03/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17-04-2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Surinder Pal ✓		
10	Year of construction	1964		
11	Applicant letter No.	MHA Portal ID 2023032504257 dated 31.03.2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements As per Old NOC/Existing Fire Safety System	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	09 mtr.	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	01 no.	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	02 nos	1.0m (2 Nos) each	MR (Old Case)
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Restt. area	12 ACPH	Exhaust fan provided	MR
5	Fire Extinguishers.			
	• Total numbers	ISI marked	05 Nos	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose-reel	01 No	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR

NA

9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors.	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	Boosting	225 LPM	MR
	➤ Head of pump.	-NA-	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	4000 Ltr	4,000 Ltr	MR (old Case)
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided 50 KVA Generator Set	MR
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

NA

✓

✓

M/s Fujiya Restaurant, 12/48, Malcha Marg, Shopping Centre, New Delhi-110021

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/SZ/2020/SZ/77 dated 19/03/2020, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

15/4/23

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

msk
19/4/23

cfb
20/4/2023

Director
20/4/23
Hony B.T.

As approved, F.T. letter is put up for
your signature pl

15/4/23

Director
21/4/23
m

uploaded
20/4/23