

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 236

Dated 06/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Shree Ji World School located at Kh. No. 23/24 Jain Colony, Prehladpur Bangar, Gurudwara Lane, Delhi-110039 comprised of Basement+ Ground+ First floor owned/ occupied by Shree Ji World School have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 31.03.2023 in the presence of Sh. Divij Babbar and that the school building is fit for occupancy Group B Educational with effect from 06/04/2023 for a period of 03 (Three) years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..06/04/2023.. at New Delhi by

(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. The Director , Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. Principal , Shree Ji World School, Jain Colony, Prehladpur Bangar , Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Shree Ji World School located at Khasra No. 23/24 Jain Colony, Prehladpur Bangar, Gurudwara Lane, Delhi – 110039.
- 2 Type of occupancy : Educational
- 3 Building composition : Basement + Ground + One upper floor.
- 4 Type of case : New case
- 5 Details of previous NOC : NIL
- 6 Fire safety directives letter no : NBC Part-IV
- 7 Date of inspection : 31 /03/2023
- 8 Name of inspecting officer : ADO (BW)
- 9 Name of designation of officer
From the building side : Sh. Divij Babbar
- 10 Year of construction : -----
- 11 Applicant's letter No. : Email ID, Dated – 26/03/ 2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	03	03	MR
	b. Width of staircases			
	• Upper Floor	1.50 m each	Provided	MR
	• Basements	1.50 m each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	All	Provided	MR
	e. Width of Corridor	1.80 m	Provided	MR
	f. Door Size	1.2 m	1.20 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	12 ac/hr	Provided	MR
	• Upper floors	12 ac/hr	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	1 @ 300 sqm	15 nos	MR
	• Types	ABC	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			

<ul style="list-style-type: none"> PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/School/2022/WZ/95 dated 27/02/2023. In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

DB
ADO(BW)
03/4/23

Signature of Inspecting Officer
 Name: Rajeev Kumar Sinha
 Designation; ADO(BW)

Do (WZ) Sankar

Chd (D.P. Bhardwaj)

[Signature]
3/4/2023

Chd
[Signature]
3/4/2023

Director (WZ)
[Signature]
5/4/23

Adv on Dir. F-T letter in Putup for sign pleap

[Signature]
ADO (BW)
05/4/23

Director (DFS)
[Signature]
5/4/23
[Signature]