

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2023/273

Dated: 19/04/2023

FIRE SAFETY CERTIFICATE

Certified that **Swami Dayanand Sarvodaya Kanya Vidyalaya located at Old Rajinder Nagar, New Delhi- 110060**, was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2015/SZ/528 dated 15.04.2015 for school building having two blocks namely senior wing & junior wing. Senior wing comprised of ground plus two upper floors and junior wing comprised ground plus one upper floor. The school building was re-inspected by the officer concerned of Delhi Fire Service on 10.04.2023 in the presence of Sh. Sunil Tarare (Estate Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 under Delhi Fire Service Act- 2007 and found that the school building is fit for occupancy class "Educational" with effect from 19/04/2023 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 19/04/2023 at New Delhi by.


 Atul Garg)

Director

Delhi Fire Service

Copy to: -

1. The Principal, Swami Dayanand Sarvodaya Kanya Vidyalaya, Old Rajinder Nagar, New Delhi- 110060.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Swami Dayanand Sarvodaya Kanya Vidyalaya, Old Rajinder Nagar, New Delhi- 60.
2. Type of Occupancy : Educational
3. Building Composition : School building is having two blocks- Senior wing & Junior wing. Senior wing is comprised of ground plus two upper floors and Junior wing is comprised of ground and first floor.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/528 dated 15.04.2015
6. Fire Safety directives letter No : N/A
7. Date of inspection : 10.04.2023
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (S. Road)
9. Name and designation of officers from the building side : Sh. Sunil Tarare (Estate Manager)
9. Year of Construction : 1960-61
10. Applicant's letter No. : letter No. SDKV/ORN/2023 dated 20.03.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 15.04.2015	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 Nos. each block	Provided	MR ✓
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	SW- 1.75, 1.60 mts., JW- 1.75, 1.45 mts	MR ✓
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 each block	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Vent.	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect. Panel.	MR

The fire protection systems provided in the building were tested / checked and found satisfactory at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/2015/SZ/528 dated 15.04.2015, renewal under Rule 37 of Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature] 11/4/23.

(P.V. Rathee)
Asstt. Div. Officer (SRD)

D.O. (S.W.)
[Handwritten Signature]
12/4/23

CFO (S2)
[Handwritten Signature]
13/4/2023

Director
[Handwritten Signature]
17/04/23
A-1157