



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Industrial/NDZ/2023/ 204

Dated: 04 / 05 / 2023

FIRE SAFETY CERTIFICATE

Certified that the PRG International Electricals Pvt. Ltd., located at B-43, Jhilmil Industrial Area, Shahdara, Delhi- 110095, comprised of Basement, Ground and First Floor only owned / occupied by PRG International Electricals Pvt. Ltd., was issued FSC vide letter No. F6/DFS/MS/2014/NDZ/1261 Dated 07/10/2014. The premises was re-inspected by the officer concerned of this department on 17/04/2023 in presence of Sh. Nilesh and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building is fit for occupancy class "Industrial" (Group-G) with effect from 04 / 05 / 2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 04 / 05 / 2023 at New Delhi by


(AJUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Manager, PRG International Electricals Pvt. Ltd., located at B-43, Jhilmil Industrial Area, Shahdara, Delhi- 110095.
2. The Commissioner of Industries, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi-110092.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. Basement shall be used strictly as per Building by -laws.

2775

INSPECTION REPORT

1. Name & address of the building : PRG International Electricals Pvt. Ltd., B-43, Jhilmil Industrial Area, Shahdara, Delhi- 110095.
2. Building is comprised of : Basement, Ground, First Floor only
3. Type of Occupancy : Industrial
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2014/NDZ/1261 Dated 07/10/2014
6. Fire Safety directives Letter No.: NBC Part-IV
7. Date of inspection : 17/04/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer from the building side : Sh. Nilesh
10. Year of Construction : 1996
11. Applicant's Letter No. : Outdoor Dairy No. 04 Dated 03/04/2023

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Guidelines Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 m	20 m	MR ✓
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 nos.	2 nos.	MR ✓
	• Basement	1 nos.	1 nos. ✓	MR ✓
	b. Width of Staircases			
	• Upper Floor	1.25 m	1.70 m & 1.25 m (old accepted)	MR ✓
	• Basement	1.25 m	1.55 m	MR ✓
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 nos.	1 nos.	MR ✓
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation			
	• Fire check Door	Required	Provided	MR ✓
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	Required	Provided	MR ✓
	• Upper Floor	Required	Provided	MR ✓
5	Fire Extinguishers			
	• Total Numbers	10 Nos.	20 Nos. ✓	MR ✓
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

02

6	First-aid-Hose Reels			
	Total numbers of each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	30 m ✓	MR
	• Nozzle diameter	05 mm	05 mm ✓	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/Heat	Smoke/Heat	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	100 mm	100 mm	MR
	• Number of Hydrants per Floor	01	01	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of Hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13	Pumping Arrangement			
	• Ground Level			
	➢ Discharge of main Pump	2280 LPM	2280 LPM ✓	MR
	➢ Head of Main Pump	40 m	40 m ✓	MR
	➢ Number of main Pumps	01	01 ✓	MR
	➢ Jockey pump output	N/A	N/A	MR
	➢ Jockey pump head	N/A	N/A	MR
	➢ Standby pump output	2280 LPM	2280 LPM ✓	MR
	➢ Standby pump head	40 m	40 m ✓	MR
	➢ Water curtain pump	N/A	N/A	MR
	➢ Auto starting/Manual stopping	Required	Auto	MR
	➢ Pump house access	Required	Provided	MR
	• Terrace Level			
	➢ Discharge of pump	900 LPM	Provided	MR
	➢ Head of the pump	40 m	40 m	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	1,00,000 Ltrs.	1,00,000 Ltrs. ✓	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage	Required	Provided ✓	MR

[Handwritten signatures and marks]

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	D.G. Set	D.G. Set /	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/2014/NDZ/1261 Dated 07/10/2014 renewal is recommended.

Ashok
24/04/2023

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.)

Dy. CFO (NDZ)

C.F.O.

AKJ
27/04/23
C.S.K. DUG

[Signature]
28/4/2023

Director

[Signature]
2/5/23

[Signature]

Sr. F.T. is added for sign. pl.

[Signature]

[Signature]
23/05/2023