

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2023/NDZ/ 207

Dated 04/05/2023

FIRE SAFETY CERTIFICATE

Certified that the **Indian National Theatre Trust (Shri Ram Centre Auditorium)** located at 4, Safdar Hashmi Marg, New Delhi in the building Comprised of **Basement + Ground + 02 upper floor**. The FSC was earlier granted FSC by this department vide letter **F6/DFS/MS/2020/Audi/NDZ/379** dated **22.09.2020** for auditorium . Now, the premises was re-inspected by the officers concerned of this department on **24/04/2023** in the presence of **Sh. Anuj (Manager)** and found that the said auditorium has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building -Group- D (Auditorium only)** with effect from **04/05/2023**..... for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued.....**04/05/2023**.....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect , NDMC , Plaika kendra New Delhi
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi
3. The Manager, Indian National Theatre Trust (Shri Ram Centre Auditorium) located at 4, Safdar Hashmi Marg, New Delhi

Conditions for the validity of Fire Safety Certificate

1. The FSC is valid only for auditorium.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

25
INSPECTION REPORT

1. Name & address of the building : **Indian National Theatre Trust (Shri Ram Centre Auditorium)** located at 4, Safdar Hashmi Marg, New Delhi in the building B+G+2 upper floor
2. Type of occupancy : Auditorium (assembly)
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/Audi/NDZ/379 dated 22.09.2020
5. Fire safety directives No. : N/A
6. Date of inspection:- 24/04/2023
7. Name of the inspecting officer : Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal, DO/CD
8. Name & designation of officer
From the building side : Sh. Anuj (Manager)
9. Year of construction : old Building
10. Applicant's letter No : letter no. 227-30/jointC.P/Lic(Amst) dated 23.02.2023

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	09 mtr.	12 mtr. ✓	MR
	2) Gate width	4.5 mtr.	4.5 mtr. ✓	MR
	3) Width of internal road	06 mtr.	Front side ✓	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	03	MR
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.5 mtr. each ✓	MR
	2. Basements	1.0 mtr.	1.10. & 1.5 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 No	02 No	MR
	E. Width of corridor	N/A	1.5 mtr. ✓	N/A
	F. Door size	1.0 Mtr.	1.5 Mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door in basement	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			

4

✓ 

N/26

	1) Total numbers	40 Nos.	44 Nos. /	MR
	2) Types	ABC & CO2	ABC & CO2 & W.Co2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	03 No.	03 No. /	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm. /	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	At ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	DG Set	DG Set	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided /	MR
	2) Upper floors (stage)	Required	Provided /	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	02	02 /	MR
	3) Hose box per floor	02	02 /	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02 /	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	Provided /	MR
	b) Head of main pump	40 meter	Provided	MR
	c) Number of main pump	01 nos	Provided	MR
	d) Jockey pump out put	180 LPM	180 LPM /	MR
	e) Jockey pump head	35 mtr.	35 mtr. /	MR
	f) Stand by pump output	1800 LPM	1800 LPM /	MR
	g) Stand by pump head	70 mtr.	70 mtr. /	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	50,000 ltr.	70,000 ltr. /	MR

6

✓

~127

	capacity			
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 Ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the auditorium of the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/2020/Audi/NDZ/379 dated 22.09.2020, under Rule 35 of the Delhi Fire Service - Rules 2010. Accordingly, DFA is prepared and put up for kind perusal and signature please

Signature of the Inspecting Officer

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- Sh. Ravinder Singh
Designation : ADO (CC)

~~Dy. C.F.O. (202)~~

Line
26/04/23

C.F.O.
26/4/2023

Director
21/5/23

AD/9