

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/Bldg/SZ/2023/SZ/203

Dated: 04/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Samavar located at B-36 Pamposh Enclave, Greater Kailash-1, New Delhi 110048 comprised of Basement and Ground floor only owned/occupied by Kashmiri Education Culture and Science Society was issued FSC by this department vide letter no. F.6/DFS/MS/Bldg/SZ/2019/93 dated 04/02/2020. The premises was re-inspected by the officers concerned of this department on 27/04/2023 in the presence of Capt. V S Rawat and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly Building," (Community Centre / Club) with effect from 04/05/2023 and valid upto 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/05/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

2023

Copy to: -

1. The Joint Commissioner of Police (LIC), 1st Floor, P.S. Defence Colony, New Delhi-110049.
2. The Executive Engineer (Bldg) Delhi Municipal Corporation, Building Department, Green Park, New Delhi 110016. (ref. 2023032904489 dated 29/03/2023)

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
5. The basement shall be used strictly as per the provisions of Building Bye Laws.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Samavar located at B-36, Pamposh Enclave, New Delhi - 110048		
2	Type of Occupancy	Assembly Building (Community Center / Club)		
3	Building Comprised of	Basement and Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F 6/DFS/MS/Bldg/SZ/2019/93 dated 04/02/2020		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2001/40 dated 08/01/2001 F6/DFS/MS/2009/1406 dated 19/05/2009		
7	Date of Inspection	27/04/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Capt. V S Rawal		
10	Year of construction	2008-09		
11	Applicant letter No	Outdoor diary no 455 dated 13-04-2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	4.3 mtr & 3m x 3	MR (old case)
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	04 Nos	03 No (enclosed) & 1 SC & ramp open	MR
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	1.50 mtr	1.3m, 1.3m, 1.3m, 1.9m & 2m ramp	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size (Exits in hall)	1.50 mtr	02 mtr & 1.50 mtr	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Nos	MR
	• Types	ISI marked	Co2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor	01 Nos	Provided	MR
	• Length of hose-reel hose	30m	Provided	MR

(Handwritten signature)

M

T

	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel	-NA-	-NA-	-NA-
	• Flow switch panel	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/Bldg/SZ/2019/93 dated 04/02/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Rajesh Kumar
Design: ADO (BCP)

DO (SD)

msl
28/4/23

CP
01/5/2023

Director
21/5/23

FFPS
WU

ADN/OLD

As approved, F.T. letter is put up for your signature pl

Director MK but up as covered 03/5/2023

ADN/OLD

F.T. letter is put up for kind peruse, Signature pl.

Dir/DFS 4/5/23

Uploaded 04/5/23

04/5/23