



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/EH/2023/NDZ/206

Dated: 04/05/2023

FIRE SAFETY CERTIFICATE

Certified that the The Hyper Café running at second floor of the building comprised of basements, ground plus seven upper floors located at Shop No. 201 to 205, Second floor Community Centre, Karkardooma, Delhi-110092, owned/occupied by A Unit of Blue Moon Café was inspected by the officer concerned of this department on dated 25/04/2023 in the presence of Mr. Praminder Choudhary and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" and valid up to 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 04/05/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c

To,

1. Sh. Praminder Singh
Shop No. 201 to 205, Second floor Community Centre, Karkardooma, Delhi-110092
2. The Joint Commissioner of Police (Lic.),
1st Floor Police Station, Defense Colony, New Delhi

MHA ID No. 2023040605505



Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/18

1. Name & address of the building : M/s The Hyper Café (A Unit of Blue Moon Café)
201, 205, 2nd floor, Plot No. 15, Community Centre,
Karkardooma, Delhi- 110092
2. Type of Occupancy : Assembly (Eating House & Bar)
3. Type of Case : New
4. Details of Previous NOC letter : Nil
5. Fire Safety directive letter No : NBC Part IV
6. Date of Inspection : 25/04/2023
7. Name of the Inspecting officers : DO, A.K. Jaiswal & ADO, Deepak Kumar
8. Name and designation of Officer from the building side : Mr. Praminder Choudhary
9. Year of Construction : 2005
10. Applicant's letter No : 2023040605505 dated 10/04/23

| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | NBC Part IV Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|-------------------------|---|----------------|
| 01 | Access to Building | | | |
| | • Road width | 09 mtr | 10 mtr | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper floor | 02 nos. | 04 nos. | MR |
| | • Basement | 02 no | 02 no | MR |
| | B. Width of Staircases | | | |
| | • Upper floor | 1.50 mtr | 1.50 mtr, 1.50 mtr 1.10 mtr & 0.94 mtr | MR |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of Exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of Continuous Staircases to Terrace | 1 no. | 1 no | MR |
| | e. Width of Corridor | 1.50 mtr | 1.50 mtr | MR |
| | f. Door Size | 02 mtr | 02 mtr | MR |
| | g. Number of Door | 02 no | 02 no | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | Required | Ventilated | MR |
| 05 | Fire Extinguishers | | | |
| | • Total numbers | 02nos | 06 nos | MR |
| | • Types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

R  50 

N/19

| | | | | |
|----|--|------------|--------------|-----|
| 06 | First-Aid-Hose Reels | | | |
| | Total numbers on each floor | 01 nos | 01 nos | MR |
| | • Length of hose reel hose | 30 mtr | 30 mtr | MR |
| | • Nozzle diameter | 05 mm | 05 mm | MR |
| 07 | Automatic Fire Detection and Alarming System. | | | |
| | • Type of detectors | Required | Provided | MR |
| | • Location of main panel | Guard Room | Provided | MR |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooter | Staircase | Provided | MR |
| 08 | MOEFA | Required | Provided | MR |
| 09 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | Provided | MR |
| | • upper floor | Required | Provided | MR |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | 100 mm | 100 mm | MR |
| | • Number of hydrants per floor | 01 no. | 01 no. | MR |
| | • Hose box | 01 no. | 01 no. | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | Provided | N/A |
| | • Hose box | N/A | Provided | N/A |
| 13 | Pumping Arrangements Common with building | | | |
| | ➤ Ground Level | | | |
| | • Discharge of main pump | N/A | 2850 LPM | N/A |
| | • Head of main pump | N/A | 60 mtr | N/A |
| | • Number of main pumps | N/A | 01 | N/A |
| | • Jockey pump out put | N/A | 180 LPM | MR |
| | • Jockey pump head | N/A | 40 mtr | MR |
| | • Standby pump out put | N/A | N/A | N/A |
| | • Standby pump head | N/A | N/A | N/A |
| | • Auto starting /manual stopping | N/A | Provided | N/A |
| | • Pump house access | N/A | Provided | N/A |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | 450 Lpm | 450 Lpm | MR |
| | • Head of the pump | 40 mtr | 40 mtr | MR |
| | • Power supply | Required | Provided | MR |
| | • Auto starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for Fire Fighting | | | |
| | • Underground tank capacity | N/A | 1,00,000 ltr | N/A |
| | • Draw-off connection | N/A | Provided | N/A |
| | • Fire service inlet | N/A | Provided | N/A |
| | • Access to tank | Required | Provided | MR |
| | • Overhead tank capacity | 20,000 ltr | 30,000 ltr | MR |
| 15 | Exit Signage | Required | Provided | MR |

Handwritten signatures and marks at the bottom of the page.

21/20

| | | | | |
|----|--|----------|----------|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of lift shaft | N/A | N/A | N/A |
| | • Pressurization of lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | Required | Provided | MR |
| | • Firemen's grounding switch | Required | Provided | MR |
| | • Lift signage | Required | Provided | MR |
| 17 | Standby Power Supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of Special Risks, if Any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings as communicated earlier vide letter no. F.6/DFS/MS/EH/2022/NDZ/1859 dated 27/05/2022 have been rectified now.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Deepak
28/04/2023.
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd)

Ajay
28/04/23
Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : DO (ED)

Dy. C.F.O. (NDZ)

RVP
01/05/23

C.F.O. Mehra
1/5/2023

FIPCL

Director
Deputy

Sir, F.P. letter is put up for sign-pl.

w. Director
AD/5/23
AD

Ajay
03/05/2023

Uploaded
04/05/23
AS