

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2023/SZ/ 280

Dated: 27/04/2023

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Laxmi Public School** located at M-29, Lado Sarai Mehrauli, New Delhi 110030 comprised of Ground plus two upper floor but **school running at Ground and First floor only** (Second floor – closed/locked) owned/ occupied by Delhi Laxmi Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2006/1329 Dated 15/06/2006. The said premise was re-inspected by officer concerned of this department on 12/04/2023 in presence of Mrs. Sunita Sejwal (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class **"Educational Building Group – B"** with effect from 27/04/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 27/04/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Delhi Laxmi Public School at M-29, Lado Sarai Mehrauli, New Delhi -30
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Delhi Laxmi Public School located at M-29, Lado Sarai Mehrauli, New Delhi 110030		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus two upper floor but school running at Ground & first floor only, second floor under lock and Key of (Land owner)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2006/1329 Dated 15-06-2006		
6	Fire Safety Directives Letter No	DOE Circular dated 17/01/2005		
7	Date of Inspection	12/04/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Sunita Sejwal (Principal)		
10	Year of construction	2006		
11	Applicant letter No.	Outdoor diary no 48 dated 03/04/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	01 No	Provided	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.25 mtr	Provided	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	Required	04 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	01 Nos	Provided	MR
	• Length of hose-reel hose	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7.	Automatic fire detection & alarming system.			

B

1

w

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	-NA-	NA
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. ➤ Pump house access. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump 	225 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		2,500 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby. Communication in lift car. Fireman's switch Lift signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel 	-NA-	-NA-	-NA-

- Flow switch panel.
- PA system panel.
- Battery backup.
- Building floor plan.

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

20. Special Fire Protection System for the Protection of special Risk, if any.

-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection and observed that school is running on rented building only on Ground and First Floor, the Second floor is under lock and key of land owner of the building and it is separated from school by partition.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/2006/1329 Dated 15/06/2006, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

18/11/2023

DO (SD)

msk
12/11

CFO
18/11/2023

Director
19/11/23

ADP/BL P

As approved, f-1 letter is put up for your signature P

18/11/23

Director
21/11/23