

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 285

Dated: 28/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Mansa Vidya Peeth located at Village Bhorgarh, Narela Delhi-110040 comprised of Ground and Two upper floors owned/occupied by Mansa Vidya Peeth was issued FSC by this department vide letter No F-6/DFS/MS/2020/158 dated 23.04.2020. The building was inspected by the officer concerned of this department on 13.04.2023 in the presence of Smt. Rajesh Bala (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from ..28/04/2023.. for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules,2010.

Issued on ..28/04/2023..... at New Delhi, by


(Atul Garg)
Director
Ph. 011-23414000


Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat ,Delhi-54.
2. The Principal, Mansa Vidya Peeth, Village Bhorgarh, Delhi-40.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N-21

INSPECTION REPORT

1. Name & address of the building : Mansa Vidya Peeth located at Village Bhorgarh, Delhi-110040.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Two Upper Floors
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2020/158 dated- 23/04/2020
6. Fire Safety directives letter No : As Per N-9
7. Date of inspection : 13 /04/2023
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Smt. Rajesh Bala (Manager)
10. Year of Construction : 2004 & 2006
11. Applicant's letter No. : E mail id , Dated-06/04/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	1.50 m	1.12 m & 0.90 m	MR(old case)
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

a z o

*

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08	Provided	MR
		ABC/Co2	ABC/Co2	MR
		Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 Nos.	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

M

w

d

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

