

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/ 138

Dated: 04/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s **Summer House Cafe** located at **First Floor, DDA Shopping Complex, Aurobindo Place Market, Hauz Khas, New Delhi 110016** in the building comprised of Ground plus One upper floor owned/occupied by A Unit of **Shaktiraj Hospitality Pvt Ltd** was issued FSC by this department vide letter no **F6/DFS/MS/EH/2020/SZ/124** dated 19/08/2020. The premises was re-inspected by the officers concerned of this department on 24/04/2023 in the presence of Mr. Anchit Kapil and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class- D "**Assembly Building**" as above and **valid upto 31/03/2026** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...04/05...../2023 at New Delhi by


**ATUL GARG
DIRECTOR
DELHI FIRE SERVICE**

Copy to: -

1. The DHO (SZ), MCD, Public Health department, Green Park, New Delhi- 110016 (Ref MHA Portal ID 2023041606592 dated 17/04/2023)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management. The trained staff should be available round the clock.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
5. Basement shall be used as per building bye laws.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Summer House Cafe, (A Unit of Shaktiraj Hospitality Pvt Ltd) located at First floor, DDA Shopping Complex, Aurobindo Place Market, Hauz Khas, New Delhi		
2	Type of Occupancy	Assembly Building "Group-D" (Restaurant is running at first floor)		
3	Building Comprised of	Ground + One Upper Floor ✓		
4	Type of Case	Renewal ✓		
5	Details of Previous NOC	F6/DFS/MS/EH/2020/SZ/124 dated 19/08/2020		
6	Fire Safety Directives Letter No	Delhi Fire Service Act-2007 and Rules 2010		
7	Date of Inspection	24/04/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Anchit Kapil		
10	Year of construction	2005-06		
11	Applicant letter No.	MHA Portal ID 2023041606592 dated 17/04/2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC (14/10/2005) requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required -N/A- -N/A-	6 m Directly accessible form the road -N/A-	MR -N/A- -N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR ✓
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	Required	1.57 & 0.75 m	MR (old case) ✓
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	Required	Two	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	Required	1.44 m	MR(old case) ✓
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH 12 ACPH	-N/A- Provided in Kitchen	-N/A- MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Required ABC / CO2 ISI marked	14 Nos ABC-10 & CO ₂ -04 Provided	MR MR MR

6. First Aid Hose Reels.				
	• Total numbers on each floor		One	MR
	• Length of hose-reel hose.	Hose Reels	30m	MR
	• Nozzle Diameter		5mm	MR
7 Automatic fire detection & alarming system.				
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	1 st floor (Reception)	MR
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8. MOEFA		Required	Provided	MR
9. Public Address System		-N/A-	-N/A-	-N/A-
10. Automatic Sprinkler System				
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	Required	Provided in Restt.	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11. Internal Hydrants.				
	• Size of Riser / Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	One	MR
	• Hose box.	Required	One	MR
12. Yard Hydrants.				
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13. Pumping arrangements.				
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 m	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14. Captive water storage for firefighting.				
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	Provided	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	5,000 ltrs	10,000 ltrs	MR
15. Exit Signage.		Required	Provided	MR
16. Provision of Lifts.				
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-

	<ul style="list-style-type: none"> • Communication in lift car. • Fireman's switch. • Lift signage. 	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	One CO ₂ type fire extinguisher provided near electrical panel	-N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on the prevention and fire safety measures as required under the rules, the NOC issued vide letter no. F6/DFS/MS/EH/2020/SZ/124 dated 19/08/2020, renewal under Delhi Fire Service Act-2007 & Rule-2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

[Signature]
21/08/2022

[Signature]
2/5/22

KTPS
[Signature]

As approved, f-1. letter is put up for your signature pl

[Signature]
2/5/22

Upland K: *[Signature]*
3/5

Uplanced *[Signature]*
8/5/23