

c16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 293

Dated: 03/05/2023

FIRE SAFETY CERTIFICATE

Certified that **Govt. Co-ed Middle School** located at **Punjab Khore, Delhi-110081** comprised of Ground Floor only owned/occupied by **Govt. Co-ed Middle School** was issued FSC by this department vide letter No F6 /DFS/MS/School/2020/98 dated 04.03.2020. The premises was inspected by the officer concerned of this department on 24.04.2023 in the presence of **Sh. Chand Singh (In-charge)**, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from 03/05/2023... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 03/05/2023... at New Delhi, by



(Atul Garg)

Director

Ph. 011-23414000



Copy to :-

1. The Director, Education, Old Secretariat, Delhi.
2. The Principal, Govt. Co-ed Middle School, Punjab Khore, Delhi-81.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N-8

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed Middle School, Punjab Khore, Delhi-110081.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground Floor Only.
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2020/98 Dated-04/03/2020
 6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 7. Date of inspection : 24/04/2023
 8. Name of Inspecting Officer : ADO, R.K.Sinha
 9. Name and designation of officers
 From the building side : Sh. Chand Singh (In-charge)
 10. Year of Construction : ---
 11. Applicant's letter No. : E mail ID , Dated-13/04/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
b.	Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
c.	Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d.	No. of continuous staircases to terrace	NA	NA	NA
e.	Width of Corridor	NA	NA	NA
f.	Door Size	1.00 m	1.00 m	MR
	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
	Smoke Management System			
	• Basements	NA	NA	NA

W

2.9

	<ul style="list-style-type: none"> Upper floors 	NA	NA	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04	Provided	MR
		ABC	ABC	MR
		Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

ac

N-10

	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	-	-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

92