



No. F6/DFS/MS/2023/School/303

Dated: 08/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary School (School ID No. 1253099) located at Mukharjee Park, (Tagore Park) Near Gurudwara, Delhi-110009 comprised of Ground & first floors only owned/ occupied by M.C. Primary School was issued Fire Safety Certificated vide this office letter no.F6/DFS/MS/School/2019/2159 dated 15.11.2019 (ground floor only). The premise was re-inspected by the officer concerned of this department on 28.04.2023 in the presence of Smt. Nectu (Incharge) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group B Educational" with effect from 08/05/2023.... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ..08/05/2023..... at New Delhi by


(Atul Garg)
Director
Ph:-011-23414000
etc

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Incharge, M.C. Primary School located at Mukharjee Park, (Tagore Park) Near Gurudwara, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/11

INSPECTION REPORT

1. Name & address of the building : M.C Primary School at Mukharjee Park, (Tagore Park) Near Gurudwara, Delhi-110009 (School ID No-1253099)
2. Type of Occupancy : Educational
3. Type of Case : Add/Alt
4. Composition of building : Ground & first floor only
5. Details of previous NOC : F6/DFS/MS/School/2019/2159 Dated 15.11.2019 (ground floor only)
6. Fire Safety directives letter No : Nil
7. Date of inspection : 28.04.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Smt. Neetu (Incharge)
10. Year of Construction : 1976-2020
11. Applicant's letter No. : Letter No. Nil Dated-18.04.2023

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education /NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.70m & 1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m & 1.20m	Provided	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	04nos	06nos	MR
	• Types	ABC Co2	ABC-06	MR
	• ISI marking	ISI Marked	Yes	MR

Sp A

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			NA
9	Public Address System.			NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A	N/A	N/A
	➢ Discharge of pump			
	➢ Head of the pump	NA	N/A	NA
➢ Power Supply	NA	N/A	NA	
➢ Auto Starting of pump	N/A	N/A	N/A	
	N/A	N/A	N/A	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	N/A	NA
15	Exit Signage.	NA	N/A	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular/ NBC Part-IV, the FSC issued vide letter of even no. 2159 dated 15.11.2019 (for ground floor only) and grant under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

DO/IV
 02/05/2023
 D. S. Munderji
 DO (HWA)
 CFO
 25/5/2023
 Director
 05/05/23

Signature of the Inspecting Officer
 Name - C. L. Meena
 Designation - ADO/RN
 01/05/2023

ADO/RN