

C 20

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 321

Dated: 15/05/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Shishu Bharti Shiksha Sadan Located at A-27, Dashrath puri, New Delhi - 110045 comprised of Ground + One Upper Floor & one room at second floor (**School running at ground floor only**) was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/2363, dated 24/12/2019. The premise was re inspected by the officer concerned of this department on 15/03/2023 in the presence of Smt. Maya Singh (Chairman). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 15/05/2023 for a period of **three years**, subject to compliance of the condition given below.

Issued on 15/05/2023. at New Delhi by.

(Arul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, Shishu Bharti Shiksha Sadan Located at A-27, Dashrath puri, New Delhi - 110045.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

119

INSPECTION REPORT

1. Name & address of the building: Shishu Bharti Shiksha Sadan Located at A-27, Dashrath puri, New Delhi - 110045
2. Type of Occupancy : Educational (Ground +One Upper Floor & 01 room at 2nd floor & School is running at Ground Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/2363, dated 24/12/2019
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 17/04/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Smt. Maya Singh (Chairman)
9. Year of Construction : 1991
10. Applicant's letter No. : Nil dated 10/04/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6, N/7 & N/8	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	NA	01 No.	NA
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	NA	One	MR (Being old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	02 mtr	NA
	f. Door Size	1 m	Provided	MR (Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

D.S.


✓


4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		Required	Natural Ventilation Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	01 no.ABC or CO ₂ For every 300 sq.mtr ISI marked	3 Provided Provided ISI marked	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
	Pumping Arrangements			
13	<ul style="list-style-type: none"> Ground Level Discharge of main pump > Head of main pump > Number of main pumps > Jockey pump out put > Jockey pump head > Standby Pump out put > Standby Pump Head > Auto Staring/Manual stopping > Pump House Access • Terrace level > Discharge of pump > Head of the pump > Power supply > Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

14. Captive water Storage for fire fighting:			
• Under ground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17. Standby power supply	NA	NA	NA
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric meter	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2019/SZ/2363, dated 24/12/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADOT/AVK


 25/4/23

CFO/(S2)
 25/4/2023


 25/4/23

P/S Spk
 Spd 27
 24/4
 ACP/psr - FIP