

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2023 / CNG / 281

Dated 20/05/2023

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) located at Kh. No. 10/10 South (01-18), Main GT Road, Village Singhola, Delhi-110040 comprised of Ground floor only owned/occupied by Indraprastha Gas Limited have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 08/05/2023 in the presence of Sh. Ravi Gupta and that the building/ premise is fit for occupancy (Hazardous) "CNG Filling Station Group 'J' with effect from 12/05/2023 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010,
Issued on 12/05/2023 at New Delhi by

(Atul Garg)
Director
Ph. 011-23414000

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhi.govt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Copy to :-

1. Chief General Manager (Project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station(IGL) located at Kh. No. 10/10, South (01-18), Main GT Road, Village Singhola, Delhi-40.
2. Type of Occupancy : CNG Filling station Group 'J' (Hazardous)
3. Building Comprised : Ground Floor only.
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F 6/DFS/MS/CNG/2019/2111 dated-16/04/2019
7. Date of inspection : 08 /05/2023
8. Name of the Inspecting Officers : ADO, R.K. Sinha
9. Name and designation of officers from the building side : Sh. Ravi Gupta
9. Year of Construction : 2022
10. Applicant's letter No. : IGL/CNGPRJ/NOC/17042023 dated 17.04.2023

CNG Dispenser-03, CNG Compressor-01, CNG Cascade-01

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	08m	30m	MR ✓
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	NA	NA	NA	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	10 nos	12 nos	MR
		ABC & Co2	01 trolley- 75 kg. each, 06-DCP, 05-Co2 & (Water mist cum foam trolley-01)	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	Type of detectors	Gas & Flame detector	Provided	MR
	Location of Main Panel	Ground Floor	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required in Panel	Provided	MR
	Hooters' Location	Ground Floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring seen in premises & Co2 flooding system found provided. 02-Hand held explosive meters.		Provided MR

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to Grant Fire Safety Certificate under Rule 35 of Delhi Fire Service Rules 2010.

ADO (2/10)
10/5/23

Dol(west)

Signature of the Inspecting Officer
Name: - Rajeev Kumar
Sinha Designation:- ADO/BW

[Signature]
10/5/2023
(M K. Chattopadhyay)

[Signature]
10/5/2023

Director

[Signature]
ADO/BW

2/1