

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/Cinema/SZ/2023/ 224

Dated: 12/05/2023

FIRE SAFETY CERTIFICATE

Certified that M/s. Liberty Cinema located at 19-B, New Rohtak Road, New Delhi, comprised of ground floor plus three upper floor (Except shops) was granted NOC by this department vide letter No. F.6/DFS/MS/Cinema/2020/194 dated 04.05.2020 was re-inspected by the officers concerned of this department on 31.03.2023 in presence of Sh. Naresh (Manager) and found that Cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class-D "Assembly Building" with effect from 12/05/2023 for a period of 3(three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules- 2010, printed below.

Issued on 12/05/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to: -

1. The Manager, Liberty Cinema at 19-B, New Rohtak Road, New Delhi-110005.
2. The District Magistrate (Central), Old Employment Exchange Building Daryaganj, New Delhi 110002.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided shall be maintained in good working conditions at all time.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Liberty Cinema located at 19-B, New Rohtak Road, New Delhi
2. Type of Occupancy : Assembly
3. Building Composition. : building comprised of ground plus three upper floor
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/Cinema/2020/194 dated 04.05.2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 31.03.2023
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. Naresh (Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : letter no. nil dated 06 march, 2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided(15 mtr.)	MR
	• Gate width	On road	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mtr.	1.67 mtr. each	MR
	• Basements	NA	NA	NA
	c. Protection of exits	-----	-----	-----
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01 No.	01 no.	MR
	g. Width of Corridor	1 mtr	1.5 mtr	MR
	h. Door Size	1.5 mtr.	1.67 mts.	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	01 in AC duct	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	• Total numbers	22 nos.	Provided	MR
	• Types	ABC, Water, CO ₂ type	Provided	MR
	• IS marking	Required	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers	05 Nos.	05 nos Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Near Staircases	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Office main lobby	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	02 Nos.	Provided	MR
	• Hose Box	02 Nos.	Provided	MR
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	450 LPM	450 LPM Provided	MR
	➤ Head of Main pump	40 mts	40 mts	MR
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM Provided	MR
	➤ Head of the pump	40 mts	40 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	N/A
	• Overhead Tank capacity	10,000 lts	Provided (10000+10000=20000 Lts.)	MR
15	Exit Signage.	Required	Provided	MR


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total Area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	CO ₂ fire extinguishers are provided in elect. Panels.	MR


The fire protection systems provided in the building were test checked and found satisfactory at the time of inspection.




Note:-In the last inspection report at N-101, than inspecting officer has mentioned the requirement of sprinkler system at upper floors and pumping arrangements of 2850 LPM with head at ground level and underground water tank 1,00,000 Ltr. ; however these installation were never installed in the cinema hall and also the inspecting officer has mentioned the same in his noting at N-110.




In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/Cinema/2020/194 dated 04.05.2020. renewal under Rule 37 the Delhi Fire Service Act- 2007 & Delhi Fire Service Rules- 2010, is recommended.

Accordingly, DFA is put up for approval & signature please.


Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)


Signature of the Inspecting Officer
Name- P.V. Rathee Divisional
Asstt. Div. Officer (S.Rd)


CFO (S2)

Director

P/5


P/5

P/5

P/5
at A