

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2023/238

Dated: 23/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Level -1 & Level-2 of Convention Centre, Administrative Building without basement & Exhibition Hall A-14 without basement, located at Pragati Maidan New Delhi, are comprised of basement, L1, L2, L3 & L4, basement, Gr. + 04 Upper floors and ground, Mez. & first floor respectively. The premises were inspected by the officers concerned of this department on 18/05/2023 in the presence of Sh. Vikas Singh GM Security, Amit Chikara, Fire Office, ITPO, Sh. Avinash, JE, MCD & Sh. Naveen Kaul AE, MCD & Sh. Gurpreet Maan, SCPL and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - L1 & L2 of Convention Centre (Assembly Occupancy - group D), - Admin Building without basement (Business Occupancy) & Exhibition Hall A-14 without basement (Assembly Occupancy), with effect from 23/05/2023.. for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 23/05/2023 at New Delhi by.


(Adul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi: Kindly to ensure the occupancy as detailed above & deviation if any.
2. The General Manager, Security, ITPO, Pragati Bhawan, New Delhi
3. Sh. Brij lal, General Manager (Architecture) D&D, ITPO, Pragati Bhawan, New Delhi
4. The Authorized signatory, Sahpoorji Pollonji and Co. Pvt. Ltd., site office ITPO, New Delhi.

Conditions for the validity of Fire Safety Certificate.

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance w.r.t. deviation in construction if any, set back area, electrical connection & installation etc. shall be verified by the concerned authority
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement in Admin building, Exhibition Hall A-14 & L1 & L2 and Halls of Exhibition hall A-14 shall not be occupied till completion of pending work as specified in letter Dated 20.05.2023 GM, ITPO, under intimation to this department.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration shall be strictly prohibited and all the wooden structure / carpet shall be fire rated.
11. The number of occupants /person in Convention Centre and Exhibition Hall shall be allowed as per occupants load as specified in UBBL /NBC part-4 and same shall be ensured by ITPO management.