

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 335

Dated 18/05/2023

FIRE SAFETY CERTIFICATE

Certified that the AIM Public School located at 26-A, Main Road, Swatantra Nagar, Narela, Delhi-110040 comprised of Ground and First Floor only owned/ occupied by AIM Public School have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on 28.04.2023 in the presence of Sh. Rajat Kaushik (Manager) and found that the building/ premises is fit for occupancy Group B Educational with effect from 18/05/2023 for a period of 03 (Three) years subject to compliance of the conditions mentioned below:

Issued on ... 18/05/2023. at New Delhi by


(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The Director , Education, Government of NCT of Delhi. Old Sect. Delhi-110054.
2. Principal , AIM Public School, 26-A, Swatantra Nagar, Narela , Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency

INSPECTION REPORT

1. Name & address of the building : AIM Public School, 26-A, Main Road, Swatantra Nagar, Narela , Delhi-110040.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + One upper floor
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Director of education circular dated : 01/03/2011
7. Date of inspection : 28 /04/2023
8. Name of Inspecting Officer : ADO, R.K. Sinha
9. Name and designation of officers From the building side : Sh. Rajat Kaushik
10. Year of Construction : -----
11. Applicant's letter No. : E Mail id , Dated-13/04/2023

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--------------------------|-------------------------------|----------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width | 6.0 m | 6.0 m | MR |
| | | 4.5 m | Directly accessible from road | MR |
| | <ul style="list-style-type: none"> • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | NA | NA | NA |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 02 | 02 | MR ✓ |
| | b. Width of staircases | NA | NA | NA |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 1.50 m each | Provided | MR ✓ |
| | c. Protection of exits | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.20 m | Provided | MR ✓ |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |

R K

| | | | | |
|-----|--|-----------------|---------------------|----|
| | <ul style="list-style-type: none"> Upper floors | 12 a/c per hour | Natural Ventilation | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 06 | 10 | MR |
| | | ABC | ABC | MR |
| | | Yes | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping | | | |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |

N E

| | | | | |
|-----|--|----|----|----|
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | - | - | - |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | - | - | - |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage. | NA | NA | NA |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

Handwritten signature