



No. F6/DFS/MS/School/WZ/2023/325

Dated:- 17/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Deepanshu Public Sr. Sec. School Located at Kamerdin Nagar, Nangloi, Delhi-110041 comprised of Ground + 02 Upper Floors & A Multi-Purpose Hall on Terrace owned/occupied by Deepanshu Public Sr. Sec. School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2020/141 Dated 03.04.2020. The said premise was re-inspected by the officer concerned of this department on 20.04.2023 in the presence of Sh. Lokesh Yadav (PGT Teacher) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 17/05/2023 for a period of three years, in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on 17/05/2023..... at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Deepanshu Public Sr. Sec. School, Kamerdin Nagar, Nangloi, Delhi-110041
3. **Following fire safety directives must be adhered to:-**
 1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
 5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
 6. All comments / directions of licensing Department shall always be permitted and followed.
 7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
 8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

16/5/23

INSPECTION REPORT

1. Name and address of the building: **Deepanshu Public Sr. Sec. School**, located at **Kamerdin Nagar, Nangloi, Delhi-110041.**
2. Type of Occupancy : Educational, (**Ground+02 Upper Floors & Hall on Terrace**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2020/141 Dated 03.04.2020
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 20.04.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Lokesh Yadav (PGT Teacher)
9. Year of Construction : 1969 & 2019
10. Applicant's letter No. : DPS/1134/51/23 dated 22.03.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements/ as per FSC dated 03.04.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	03	MR ✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.76 m x 1, 1.5 m x 1 & 1.30 m x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	03	MR
	e. Width Of Corridor	1.5 m	Provided	MR ✓
	f. Door Size	1 m (G+02) 1.5 m (Hall)	1 m (G+02) 2 m x 3 (Hall)	MR ✓
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 nos. ABC & CO ₂ ISI marked	20 nos. Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 01 Provided	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA 450 lpm & 180 lpm Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA NA NA NA 10,000 ltrs.	NA NA NA NA Provided	NA NA NA NA MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/2020/141 Dated 03.04.2020 is recommended under rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007..

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
Aman Kumar Lathar
ADO (JWP)

DO (w)
WESTY...S...6
ED...04/13

SP (DPB)
25/4
27/4/2023

CPD
28/4/2023

Director
28/4/2023
P/Oy SP

submission to
spoken regarding form J+K and
details of School Building's perform
from School management to be
submitted on each renewal of FS

Sir,
As spoken on dated 03.05.23 form J, K & performance
of School building details collected from
School, duly filled, and placed opposite for
reference.
05/05/23