

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

C.56


No. F6/DFS/MS/School/SZ/2023/347

Dated: 22/05/2023

FIRE SAFETY CERTIFICATE

Certified that **Faith Academy** located at **John L. Dorsey Road, Prasad Nagar, New Delhi- 110005** was granted Fire Safety Certificate vide letter No. F6/DFS/MS/School/SZ/2020/153 dated 13.04.2020 for three blocks- Phase 1, Phase 2 & Phase 3. Phase- 1 is comprised of small basement, ground plus four upper floors & phase- 2 is comprised of ground plus four upper floors & Phase- 3 comprised of basement (sealed by brick wall), ground plus three upper floors and all blocks at upper floors are interconnected at each floor level. The school building was re-inspected by the officers concerned of Delhi Fire Service on 28.04.2023 in the presence of Sh. Anil Lal (Admin) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 22/05/2023 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 22/05/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
d/c

Copy to :-

1. The Principal, Faith Academy, John L. Dorsey Road, Prasad Nagar, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Faith Academy, John L. Dorsey Road, Prasad Nagar, New Delhi- 110005.
2. Type of Occupancy : Educational
3. Building Composition : The said school building is having 03 blocks i.e. Phase- 1 is comprised of small basement, ground plus four upper floors. Phase- 2 is comprised of ground plus four upper floors & phase- 3 is comprised of basement, ground plus three upper floors. All blocks at upper floors are interconnected at each floor level. Phase- 3 basement closed by brick wall.
4. Type of Case : Renewal ✓
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2020/153 dated 13.04.2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 28.04.2023
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. Anil Lal (Admin)
9. Year of Construction : Phase- 1 & 2- 1987-88, Phase- 3- 2017
10. Applicant's letter No. : Letter no. Nil dated 21.04.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per UBBL/NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	03 Nos.	03 Nos.	MR
	• Basements	Phase- 1- 02 nos., Phase- 3- Basement closed	Phase- 1- 02 nos., Phase- 3- Basement closed	MR ✓
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	Phase- 1- old case Phase- 3- Basement closed	Phase- 1- 91, 92 cms Phase- 3- Basement closed	MR, old case
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	03 Nos.	03 Nos.	MR
	e. Width of Corridor	1.50 mts	Provided	MR
	f. Door Size	Ph- 1&2- 01 mt. c/room door. Ph- 3- 120 cms, MP hall- 150 cms in phase- 2	Ph- 1&2- 110 cms in C/room, Ph- 3- 90 cms, MP hall- 180, 105 & 105 cms	MR in ph- 1&2 C/room, NMR in Ph- 3 C/room. MR being old case in MP hall
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans are provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation provided	MR
5	Fire Extinguishers			
	• Total numbers	07 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	Basement closed in ph-3. area of basement in ph-01 is approx. 100 sq. yards	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM in Phase- 01 & 02 and 450 - 2 LPM in Phase- 03	Provided	MR
	➤ Head of the pump	45 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			


N/26


	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Phase- 1- 5000 Its Phase- 2- 5000 Its Phase- 3- 15000 Its	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total Area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.


In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter F.6/DFS/MS/School/SZ/2020/153 dated 13.04.2020, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.


 Signature of the Inspecting Officer
 Name- Vedpal Chhikara
 Divisional Officer (SW)


 Signature of the Inspecting Officer
 Name- P V Rathee
 Asstt. Div. Officer (S Rd)

CFO (S2) 
 08/01/2023

 के साथ यह प्रतिलिपि फाइल में रखी जायेगी
 13/01/2023