



No. F6/DFS/MS/School/WZ/2023/ 334

Dated:- 18/05/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School Located at Avantika, Sector-1, Rohini, Delhi-110085 comprised of 03 blocks, 02 block-Ground + 01 Upper Floor & 01 block-Ground + 03 Upper Floors only owned/occupied by Govt. Sarvodaya Kanya Vidyalaya, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2020/WZ/261 Dated 04.08.2020. The said premise was re-inspected by the officer concerned of this department on 28.04.2023 in the presence of Ms. Sonia Bhatia (Principal) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance NBC (Part-IV)/D.O.E., GNCT of Delhi, Circular no 3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 18/05/2023 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 18/05/2023 at New Delhi by:

(Amit Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School, Avantika, Sector-1, Rohini, Delhi-110085.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: **Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School Located at Avantika, Sector-1, Rohini, Delhi-110085**
2. Type of Occupancy : Educational, 03 Blocks (BL-1&2-G+01 & BL-3-G+03)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/WZ/261 Dated 04.08.2020
5. Fire Safety directives Letter No. : NBC (Part-IV)/D.O.E Cr.no.3298-3398 dated 01-03-2011
6. Date of inspection : 28.04.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Ms. Sonia Bhatia (Principal)
9. Year of Construction : 2017
10. Applicant's letter No. : form 'J' dated 28.02.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 04.08.2020	Provided at site	Remarks MR/NMR
1.	Access of building <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 m 4.5 m NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits <ul style="list-style-type: none"> <li>a. Number of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> </li> <li>b. Width of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> </li> <li>c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul> </li> <li>d. No of continuous staircase to terrace</li> <li>e. Width Of Corridor</li> <li>f. Door Size</li> </ul>	BL-1&2 01 BL-3 02 NA 1.5 m NA NA NA 01 Required 1 m	BL-1&2-01 BL-3 03 NA BL-1-1.50 m BL-2-1.50 m BL-3-1.90 m x 03 NA NA NA 02 Provided 1.10 m NA NA NA NA	MR NA MR NA NA MR MR MR MR MR
3.	Compartmentation <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System <ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA 12 a/c per hour	NA Natural Ventilated	NA MR

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	40 nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 30 m 05 mm	03 Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	Provided Provided 01	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA NA NA 450 lpm x 2 Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 10,000 ltrs.	1,00,000 ltrs. NA NA NA Provided	NA NA NA NA MR MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2020/W/261 Dated 04.08.2020 is recommended.

Accordingly DFA is put up for approval please.

*Aman Kumar Lathar*  
 08/05/23  
 Aman Kumar Lathar  
 ADO (JWP)

~~DO (w)~~  
~~DO (w)~~  
~~CFO (w)~~

Hospitaline

Send file through Doc west)

~~ADO (JWP)~~

~~12/5/2023~~

*Quitted*  
 15/5/23  
 ADO (JWP)

~~DO (w)~~

*15/5*

~~CFO~~

*15/5/2023*

~~Director~~  
 13/5/23

H P 9  
 ADO (JWP)

~~Director~~  
 17/5/23

Sri. F.S. letter is put-up for your signature pl.

*Quitted*  
 11/5/23  
 ADO (JWP)