

025


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023/School/WZ/336

Dated 19/05/2023

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Co-ed School** located at **Hamidpur, Delhi-110036** comprised of **Ground + One upper floor** owned/ occupied by **M.C. Primary Co-ed School** have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 3298-3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on **12.05.2023** in the presence of **Sh. Chand Ram (Principal)** and found that the building/ premises is fit for occupancy **Group B Educational** with effect from 19/05/2023 for a period of **03 (Three) years** subject to compliance of the conditions mentioned below:
Issued on 19/05/2023..... at New Delhi by


(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, MCD, Civic Center, Delhi..
2. The Principal, M.C. Primary Co-ed School, Hamidpur, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Co-ed School, Hamidpur, Delhi-110036.
 2. Type of Occupancy : Educational
 3. Building comprised : Ground+ One upper floor
 4. Type of Case : Renewal/Add /Alteration.
 5. Details of Previous NOC : F.6/DFS/MS/School/2015/WZ/1714 Dated-18/09/2015 (Ground Floor) ✓
 6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 7. Date of inspection : 12/05/2023
 8. Name of Inspecting Officer : ADO R.K Sinha
 9. Name and designation of officers
 From the building side : Sh Chand Ram (Teacher Incharge)
 10. Year of Construction : 2018
 11. Applicant's letter No : E Mail id, Dated-19/04/2023

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--------------------------|---------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 6 m | 6 m | MR |
| | • Gate width | Directly Accessible | Directly Accessible | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | NA | NA | NA |
| | • Upper Floors | 02 | 03 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | NA | NA | NA |
| | • Upper Floor | 1.50 m each | 1.50 m × 2 & 1.35 m | MR ✓ |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.20 m | 1.20 m double door | MR ✓ |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | NA | NA | NA |

ae

fy

| | | Required | Natural Ventilated | MR |
|-----|---|----------|--------------------|------|
| | <ul style="list-style-type: none"> Upper floors | | | |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers | 08 | 09 | MR |
| | <ul style="list-style-type: none"> Types | ABC | ABC/Co2 | MR ✓ |
| | <ul style="list-style-type: none"> IS marking | Yes | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Length of hose reel hose | NA | NA | NA |
| | <ul style="list-style-type: none"> Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Main Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Repeater Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Alternate source of power | NA | NA | NA |
| | <ul style="list-style-type: none"> Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement | NA | NA | NA |
| | <ul style="list-style-type: none"> Ground Floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | NA | NA | NA |
| | <ul style="list-style-type: none"> Number of hydrants per floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main Pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Head of Main pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Number of main pumps | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey pump head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump Head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | | NA | NA | NA |

2

| | | | | |
|--|--|----|----|----|
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | - | - | - |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | - | - | - |
| | ➤ | NA | NA | NA |
| Captive Water Storage for fire fighting | | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| Exit Signage. | | | | |
| Provision of Lifts. | | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| | | NA | NA | NA |
| Standby power supply | | | | |
| Refuge Area. | | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| Fire Control Room | | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

N

h