

e 26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2023/SZ/331

Dated: 18/05/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of **MCD Primary CO-ED School**, Pratap Nagar, New Delhi-110064, comprised ground plus one upper floor, owned/occupied by MCD Primary CO-ED School was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ/172 dated 29/04/2020. The school building was re-inspected by the officer concerned of this department on 10/05/2023 in the presence of Smt. Manju Vig (Principal) and found that School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the school building/ premises (**School Block Only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under:

Issued on 18/05/2023 at New Delhi.

  
**ATUL GARG**  
**DIRECTOR**  
**DELHI FIRE SERVICE**

Copy to:-

1. The Principal,  
MCD Primary School,  
Pratap Nagar, New Delhi-110064
2. Director of Education,  
MCD, Civic Centre,  
Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. This Fire Safety Certificate is not valid for Auditorium Block.

## INSPECTION REPORT

1 Name & address of the building	MCD Primary School, Pratap Nagar, New Delhi-110064
2 Building comprised of	2 blocks namely School Block (G-1) & Auditorium Block (G+1) is not with school management
3 Type of Occupancy	Educational
4 Type of Case	Renewal
5 Details of Previous NOC	F 6/DFS/MS/School/2020/SZ/172 dated 29/04/2020 (For school block)
6 Fire Safety directives letter No	Circular No F 16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7 Date of inspection	10/05/2023
8 Name of Inspecting Officer	A.D.O. R.K. Yadav
9 Name and designation of officers from the building side	Smt. Manju Vig (Principal)
10 Year of Construction	2016
11. Applicant's letter No	Nil dated 14/04/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 4.5 mtrs. N/A	12 mtrs 4.5 mtrs (02 no's) N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a Number of staircases			
	• Upper Floors	02 No's	02 No's	MR
	• Basements	N/A	N/A	N/A
	b Width of staircases			
	• Upper Floor	1.5 m each	1.5 m each	MR
	• Basements	N/A	N/A	N/A
	c Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d No. of continuous staircases to terrace	Required	One	MR
	e Width of Corridor	1.50 m	2.50 m	MR
	f Door Size	1.2 m	1.20m (double door)	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural Ventilation	M/R
5.	<b>Fire Extinguishers</b>			
	• Total numbers	05 no's	Provided	MR
	• Types	ABC/CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A







**Fire Control Room**

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Battery backup
- Building Floor Plans

N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

20. **Special Fire Protection System for Protection of special Risks, if any:**

N/A	N/A	N/A
-----	-----	-----

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2020/SZ/172 dated 29/04/2020 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended

Note:- Auditorium block is not considered as it is not with school management

*R.K. Yadav*  
18/5/2023

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

*[Signature]*  
12/8/23

*[Signature]*  
15/5/2023

*[Signature]*  
15/05/23

*[Signature]* R.K. Yadav / DM

F T, letter e put up for sign. please

*[Signature]*  
17/5/23

*[Signature]*  
19/5/2023