

240

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2023 / School / WZ / 329

Dated: 18/05/2023

FIRE SAFETY CERTIFICATE

Certified that **Mount Abu Public School** located at **Sector-18, Rohini, Delhi-110085** comprised of **Ground and Three upper floors** owned/occupied by **Mount Abu Public School** was issued FSC by this department vide letter No **F-6/DFS/MS/2018/School/WZ/1537** dated 03.07.2018. The building was inspected by the officer concerned of this department on 29.04.2023 in the presence of Sh. Manish Arora (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from 18/05/2023..... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/05/2023..... at New Delhi, by

  
(Atul Garg)  
Director

Ph 011-23414000

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Principal, Mount Abu Public School, Sector-18, Rohini, Delhi-85.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building :	Mount Abu Public School located at Sector-18, Rohini, Delhi-85
2. Type of Occupancy :	Educational
3. Building Comprised :	Ground + Three Upper Floors
4. Type of Case :	Renewal
5. Details of Previous NOC :	F6/DFS/MS/2018/School/WZ/1537 dated- 03/07/2018
6. Fire Safety directives letter No :	NBC Part-IV
7. Date of inspection :	29 /04/2023
8. Name of Inspecting Officer :	ADO, R.K.Sinha
9. Name and designation of officers From the building side :	Sh. Manish Arora (Manager)
10. Year of Construction :	---
11. Applicant's letter No. :	E Mail ID., Dated-23/01/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	03	MR ✓
	• Basements	NA	NA	NA
	b. Width of staircases	1.50 m each	1.50 m each	MR ✓
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	03	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR

il

4

Q

N-10

5.	<b>Fire Extinguishers</b>			
	• Total numbers	17	Provided	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• IS marking	Yes	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	02 Nos.	02 Nos.	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	02	MR
	• Hose Box	02	02	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	01	01	MR
	• Hose Box	01	01	MR
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

22

Hj

	<ul style="list-style-type: none"> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	<p style="text-align: center;">-</p> <p>450 lpm &amp; 180 lpm</p> <p>40 m</p> <p>Required</p> <p>-</p> <p>Required</p>	<p style="text-align: center;">-</p> <p>Provided</p> <p>40 m</p> <p>Provided</p> <p>-</p> <p>Provided</p>	<p style="text-align: center;">-</p> <p>MR</p> <p>MR</p> <p>MR</p> <p>-</p> <p>MR</p>
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>15,000 ltrs</p> <p>Required</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>15,000 ltrs</p> <p>Provided</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>MR</p> <p>MR</p>
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
17.	<b>Standby power supply</b>			
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

N

X