



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Club/2023/SZ/ 255

Dated: 25/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Delhi Gymkhana Club located at No-2, Safdarjung Road, New Delhi-110011 comprised of Ground Floor Only owned / Occupied Delhi Gymkhana Club, has already been issued Fire Safety certificate vide letter no. F6/DFS/MS/club/2020/291 Dated 31/07/2020. The premises was re-inspected by the officers from this department on dated 06/05/2023 in the presence of Sh. Meharban Singh Negi (Manager) and observed that all the Fire prevention & Fire Safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from 25/05/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/05/2023 at New Delhi.


(ATUL GARG)
DIRECTOR

Copy to:-

1. M/s Delhi Gymkhana Club located at No-2, Safdarjung Road, New Delhi-110011.
2. The Medical Officer of Health, NDMC, Palika Kendra, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT 11/32

- Name & address of the building : M/s Delhi Gymkhana Club located at No.2, Safdarjung road, New delhi-110011.
1. Type of Occupancy : Group-D, Assembly Building (Club house)
2. Type of case : Renewal
3. Building comprised of : Ground floor only
4. Details of previous NOC : F6/DFS/MS/club/2020/291 Dated 31/07/2020
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 06/05/2023
7. Name of the Inspecting Officer : DO(SD) M.K Sharma & A D.O. (S.J.) Santosh Kumar
8. Name and designation of Officer from the building side : Sh. Meharban Singh Negi (Manager)
9. Year of Construction : Not known
10. Applicant's letter received through email dated 01/05/2023 & (MHA ID-

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Old Noc Requirements | Provided at site | Remarks MR/NMR |
|------|---|--------------------------------|---|----------------|
| 1. | Access of building | | | |
| | • Road width | Accessible | 9m | MR |
| | • Gate width | Required | 4.5m (02nos) | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | NA | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | Required | 02Exit in each eating house | MR(old case) |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | 12 ACPH | Exhaust fans & Natural Ventilation provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 30 Nos | 30 nos | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | MR |
| | • ISI marking | Required | Provided | MR |

21/32

| | | | | |
|----|-------------------------------|--------|----------|------|
| 6. | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | 12 nos | 12 Nos | MR |
| | • Length of hose reel hose | 30m | Provided | MR ✓ |
| | • Nozzle diameter | 5mm | Provided | MR |

| | | | | |
|----|--|----|----|----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |

| | | | | |
|----|-------|----------|----------|------|
| 8. | MOEFA | Required | Provided | MR ✓ |
|----|-------|----------|----------|------|

| | | | | |
|----|-----------------------|----------|----------|----|
| 9. | Public Address System | Required | Provided | MR |
|----|-----------------------|----------|----------|----|

| | | | | |
|-----|---------------------------------|----|----|----|
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |

| | | | | |
|-----|--------------------------------|----|----|----|
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |

| | | | | |
|-----|----------------------------|----|----|----|
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |

| | | | | |
|-----|---------------------------------|----------|------------------|--------------|
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | Required | 450 LPM & 180LPM | MR(old case) |
| | > Head of main pump | Required | 70m & 40m | MR(old case) |
| | > Number of main pumps | Required | 01Nos | MR(old case) |
| | > Jockey pump out put | NA | NA | NA |
| | > Jockey pump head | NA | NA | NA |
| | > Standby Pump out put | NA | NA | NA |
| | > Standby Pump Head | NA | NA | NA |
| | > Auto Starting/Manual stopping | Required | Provided | MR |
| | > Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | > Discharge of pump | NA | NA | NA |
| | > Head of the pump | NA | NA | NA |
| | > Power supply | NA | NA | NA |
| | > Auto starting of pump | NA | NA | NA |

| | | | | |
|-----|---|-------------|----------|----------------|
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | > Draw of connection | NA | NA | NA |
| | > Fire service inlet | NA | NA | NA |
| | > Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 15,000 Ltrs | Provided | MR(old case) ✓ |

CF
wii
ivec
saf
/cu
A C
(SD)

m

| 15 | Exit Signage | Required | Provided | MR |
|-----|--|----------|------------------------------|------|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | Provided 50kva Generator set | MR ✓ |
| 18. | Refuge Area | | | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the DOE circular, FSC Issued Vide letter No. F6/DFS/MS/club/2020/291 Dated 31/07/2020 renewal under rules 37 of the Delhi fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj
18/5/23
Signature of the Inspecting Officer
Name : Manoj Kumar Sharma
Designation : DO (SD)

Santosh
16.05.23
Signature of the Inspecting Officer
Name : Santosh Kumar
Designation : A D.O. (S.J.)

Please Speak

C/S
Manoj
17/5/2023

Director
~~DO (South)~~

1- Spoken on 17.5.2023 regarding beating cap which is 190/ please.
2- Submitted for approval please.

Director
Manoj
18/5/23

Manoj
17/5/2023