

C 20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/EH/2023/SZ/159

Dated: 22/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Himalaya Sagar (A unit of M.L. Hospitality Service Private Limited) running at ground & first floor only, in a building comprised of ground plus three upper floors located at A-1, Milap Nagar, Uttam Nagar, New Delhi-110059, owned/occupied by M/s Himalaya Sagar (A unit of M.L. Hospitality Service Private Limited) have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rule 2010 and verified by the officers concerned of this department on 08/05/2023 in the presence of Sh. Lalit Khurana (Owner) and found that the building (ground & first floor only) is fit for occupancy 'Class D "Assembly Building"(Restaurant) ' for with effect from 22/05/2023 for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on... 22/05/2023at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
9/20

To,

M/s Himalaya Sagar (A unit of M.L.Hospitality Service Private Limited),
A-1, Milap Nagar, Uttam Nagar, New Delhi-110059.

Copy to:-

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

- This NOC is valid only for ground & first floor.
- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency
- All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s Himalaya Sagar (A unit of M.L Hospitality Service Private Limited), A-1, Ground floor & first floor, Milap Nagar, Uttam Nagar, New Delhi-110059.
2. Building is comprised of : G+3 floors But eating house running at Gr. & FF only
3. Type of Occupancy : Assembly (Eating Housing)
4. Type of Case : New ✓
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 08/05/2023
8. Name of the Inspecting officers : ADO R.K. Yadav & DO Vedpal Chhikara ✓
9. Name and designation of Officer from the building side : Sh. Lalit Khurana (Owner)
10. Year of Construction : 1998
11. Applicant's letter No : ID No. 2023042807696 Dated 28/04/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	Provided	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 m each	Provided	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR ✓
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2m & 1.5 m	2m & 1.5 m at gr. & 2x 1.5 m at FF	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ABC /CO ₂	Provided	MR ✓
	• IS marking	ISI marked	Provided	MR

ES

hu

First-Aid-Hose Reels.			
Total numbers on each floor • Length of hose reel hose • Nozzle diameter	01 No.	Provided	MR
	30 m	Provided	MR
	05 mm	Provided	MR
Automatic Fire Detection and Alarming System.			
• Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power • Hooter's location	Smoke	Provided	MR
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
MOEFA	Required	Provided	MR
Public Address System.	N/A	N/A	N/A
Automatic Sprinkler System.			
Basement • ground floor • sprinkler above false ceiling	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
Internal Hydrants			
• size of riser/down-comer • Number of hydrants per floor • Hose box	100 MM	Provided	MR
	01 No.	Provided	MR
	01 No	Provided	MR
Yard Hydrants			
• Total number of hydrants • Hose box	N/A	N/A	N/A
	N/A	N/A	N/A
Pumping Arrangements.			
➤ Ground Level			
• Discharge of main pump • Head of Main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby pump out put • Standby pump head • Auto starting /manual stopping • Pump house access	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
➤ Terrace Level			
• Discharge of pump • Head of the pump • Power supply • Auto starting of pump	450 Lpm	450 Lpm	MR
	40 M	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14 Captive Water Storage for Fire Fighting.			
• Underground tank capacity • Draw-off connection • Fire service inlet • Access to tank • Overhead tank capacity	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	20,000 Ltrs.	20,000 Ltrs	MR
15 Exit Signage.	Required	Provided	MR
16 Provision of Lifts.			
• Pressurization of lift Shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A

17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

The total covered area of the eating house at GF & FF is 334 sq. meters. As per Part-IV, NBC-2016, Total the number of persons will come Approx. 186 ($334/1.8 = 334$) for the restaurant.

R.K. Yadav
15/5/2023

Signature of the Inspecting Officer
Name :- R.K. Yadav
Designation:- ADO (JKP)

Vedpal Chhikara
16/5/23

Signature of the Inspecting Officer
Name :- Vedpal Chhikara
Designation:- DO (South West)

CFO (South Zone)

Hugh
16/5/2023

Detector for
17/05/23

DO SW
Vedpal 17/5

gcrh check the area again. It seen to be near Area 270sq mt.

ADO (JNKPURI)

So, total area is 334 sqmeters as per the application and sweet shop is running at ground floor having no seating arrangement and restaurant is at 1st floor and total area of the 1st floor is about 167 sqmeters.

FT holder is also put up here for candidate's pt.

R.K. Yadav
18/5/23