

c-6

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/SZ/2023/EH/160

Dated: 24/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant, Located at Ground Floor, Plot No. 228, Sector - 9, Dwarka, New Delhi - 110075, in a building comprised of Basement + Ground + 03 Upper Floors, owned/ occupied by **Sapphire Foods India Ltd.** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 16/05/2023 in the presence of Mr. Santosh (Manager) and found that the said building/premises is fit for occupancy class "Assembly" Group D (Ground floor) with effect from 24/05/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/05/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, M/s KFC Restaurant, at Ground Floor, Plot No. 228, Sector - 9, Dwarka, New Delhi - 110075.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant Located at Ground Floor, Plot No. 228, Sector - 9, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Assembly 'D' Restaurant running at Ground Floor, (The building comprised of B + G+ 3 U.Fs) :
3. Type of Case ; New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : UBBL & NBC Part IV
6. Date of inspection : 16/05/2023
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Santosh (Manager)
9. Year of Construction : 2000
10. Applicant's letter No. : 2023051208767 dated 12-05-2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x1.5 mtr	Provided	MR ✓
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR ✓

5.	Fire Extinguishers			
	• Total numbers	3 nos. each floor	4 Nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Smoke	MR
	• Location of Main Panel	Ground Floor	Near office	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Battery Backup	MR
	• Hooters' Location	Required	Stairs	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	2280 lpm	NA
	➤ Head of main pump	NA	50 mtr	NA
	➤ Number of main pumps	NA	01	NA
	➤ Jockey pump out put	NA	180 lpm	NA
	➤ Jockey pump head	NA	50 mtr	NA
	➤ Standby Pump out put	NA	2280 lpm	NA
	➤ Standby Pump Head	NA	50 mtr	NA
	➤ Auto Staring/Manual stopping	NA	Provided	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm.	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	100000 ltrs	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000Ltr	10,000 ltr	MR as tank at G level at higher side
15	Exit Signage	Required	Provided	MR

No

16. Provision of Lifts				
➤	Pressurization of Lift Shaft	NA	NA	NA
➤	Pressurization of lift lobby	NA	NA	NA
➤	Communication in lift Car	NA	NA	NA
➤	Fireman's Grounding Switch	NA	NA	NA
➤	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18. Refuge Area				
➤	Total area	NA	NA	NA
➤	Location	NA	NA	NA
19. Fire control room				
➤	Detector system panel	NA	NA	NA
➤	Flow Switch Panel	NA	NA	NA
➤	PA System Panel	NA	NA	NA
➤	Battery backup	NA	NA	NA
➤	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

Note: - UG tank & pump house of higher side are provided at G. level.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010

1. M/s KFC Restaurant Located at Plot No. 228, Sector - 9, Dwarka, New Delhi - 110075.
2. As per letter/ plan submitted by the applicant the area of the restaurant is 120.77 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 67.09(120.77/1.8=67) for whole restaurant.
4. The total seating capacity comes out be 67.

Sign. Of Inspecting Officer
 Name Sh. Vedpal
 Designation DO/SW

Sign of Inspecting Officer
 Name Uday Vir Singh
 Designation ADO/DWR

CFO (S2)

A. Singh
 19/5/2023

Director

19/5/22

D/SW