

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2023/353

Dated: 25/05/2023

FIRE SAFETY CERTIFICATE

Certified that the left out block of Sarvodaya Kanya Vidyalaya, Shadi Khampur, New Delhi- 08, comprised of ground plus three upper floors. The school building was inspected by the officer concerned of Delhi Fire Service on 08.05.2023 in the presence of Er. Sonali Batta, Ex. Engineer (PWD) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Act 2007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 25/5/2023 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed blow.

Issued on 25/5/2023 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

dc 4

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, Shadi Khampur, New Delhi- 08.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

N/30

INSPECTION REPORT

1. Name & address of the building : Left out Block of Sarvodaya Kanya Vidyalaya, Shadi Khampur, New Delhi- 08.
2. Type of Occupancy : Educational
3. Building Composition : Building comprised of ground plus three upper floors provided only 02 class rooms at each floor (left out Block). ✓
4. Type of Case : New Case ✓
5. Details of previous NOC : N/A ✓
6. Fire Safety directives letter No : N/A
7. Date of inspection : 08.05.2023
8. Name of the Inspecting Officers : P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Er. Sonali Batta, Ex. Engineer (PWD)
9. Year of Construction : 2022 ✓
10. Applicant's letter No. : Online email Id ceepwddelhim153@gmail.com dated 21.04.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts	1.78 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.50 mts	1.80 mts	MR
	h. Door Size	1.20 mts	1.20 mts	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Vent.	MR
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR

	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 Nos.	01 Nos.	MR
	• Length of hose reel hose	30 m	Provided	MR /
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM x 02 nos	450 LPM x 02 nos.	MR
	➤ Head of the pump	40 mts	40 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR /
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 lts	10,000 lts	MR
15	Exit Signage.	Required	Provided	MR /

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	✓ Total Area	N/A	N/A	N/A
	✓ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect Panel.	MR

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

Note:- Only 02 class rooms provided at each floor level.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature]
9/15/23

(P.V. Rathee)
Asstt. Div. Officer (SRD)

D.O. (SN)
[Handwritten Signature]
9/18/23

CFO (S2)
[Handwritten Signature]
15/09/2023

[Handwritten Signature]
15/09/23

Asstt. Dir. = on m/R
FT letter is put up for sign
DIRECTOR / D/S
[Handwritten Signature]
24/9/23