

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/Indl./2023/SZ/ 245

Dated: 23/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s SMS Exports located at Plot no W-7, Industrial area, Phase-II, New Delhi-110020 comprised of Basement, Ground plus One Upper floor was issued FSC by this department vide letter No. F6/DFS/MS/Indl./2020/SZ/08 dated 09/01/2020. The building was re-inspected by officer concerned of this department on 15/05/2023 in the presence of Mr. Manoj Kumar and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises/building is fit for occupancy **Group G "Industrial"** with effect from 23/05/2023 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 23/05/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. M/s SMS Exports located at Plot No W-7, Industrial area, Phase-II, New Delhi-110020.
2. The Executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management. The trained staff should be available round the clock.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
5. Basement shall be used as per building bye laws.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M/s SMS Exports at Plot no W-7, Industrial area, Phase-II, New Delhi-110020		
2	Type of Occupancy	Group-G (Industrial)		
3	Building Comprised of	Basement, Ground plus One Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Indl/2020/SZ/08 dated 09/01/2020		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2013/1559 dated 11/06/2013		
7	Date of Inspection	15/05/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Manoj Kumar		
10	Year of construction	1982		
11	Applicant letter No.	Outdoor diary no. 1580 dated 02/05/2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	6 m	Provided	MR
	➤ Gate width	5 m	Provided	MR
	➤ Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Two	Provided	MR
	➤ Basement floor.	Two	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.25m	1.30m & 1.40m	MR
	➤ Basement floor	1.25m	1.30m & 1.50m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR ✓
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA- ✓
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust Fan Provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR ✓
5.	Fire Extinguishers.			
	• Total numbers	26 Nos	26 nos	MR
	• Types	ABC /CO ₂ /W.CO ₂	10/06/10	MR

	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Every floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Above floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	150 mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	04 nos	MR
	• Hose box	Required	04 nos	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump.	60 m	Provided	MR
	➤ Number of main pumps.	Two	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	60 m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	60 m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump house access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	1,00,000 Ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR

	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car	NA-	NA-	NA-
	• Fireman's switch.	NA-	NA-	NA-
	• Lift signage	NA-	NA-	NA-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	CO ₂ extinguisher provided	MR

The fire protection system provided in the building was test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no F6/DFS/MS/Indl/2020/SZ/08 dated 09/01/2020, renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended

Accordingly, DFA is put up for approval and signature please

15/12/15

Signature of the Inspecting Officer
Name : Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (SD)

msk
17/5
C/o Vnegh
18/5/2023
Director
10/5/20

Handwritten signature