

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

Dated 16/05/2023

No F6/DFS/MS/2023/ 233

FIRE SAFETY CERTIFICATE

Certified that the Manakalya Bhawan located at 9, Bahadur Shah Zafar Marg, New Delhi - 110002, is comprised of Basement + Ground + 04 Upper floors owned/occupied by Manak Bhawan was issued earlier FSC by this department vide letter No. F6/DFS/MS/2003/NDZ/2689 dated 31/10/2003. Now, the premises was re-inspected by the officer concerned of this department on 04/05/22 in the presence of Sh. Anuj, Dy. Director and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Business Building with effect from 16/05/2023..... for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 16/05/2023.....at New Delhi by,


(Anuj Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Executive Engineer (E), CPWD, Safdarjung Hospital Electrical Division, New Delhi
2. Sh. Sakuram Gugulothu ,Project management and works department, Room No 308-09, BIS Manakalya Bhawan 9, Bahadur Shah Zafar Marg, New Delhi - 110002.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

12
INSPECTION REPORT

1. Name & address of the building : **Manakalya Bhawan** 9, Bahadur Shah Zafar Marg, New Delhi - 110002.
2. Type of occupancy : **Business Building B + G + 04 upper floor**
3. Type of case:- : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2003/NDZ/2689**
dated 31/10/2003
5. Fire safety directives No. : **12 point inspection**
6. Date of inspection:- : **04/05/2023.**
7. Name of the inspecting officer : **Sh. Ravinder Singh ADO/CC**
Sh. Rajinder Atwal , DO (CD)
8. Name & designation of officer
From the building side : **Sh. Anuj, Dy. Director**
9. Year of construction : **1957**
10. Applicant's letter No : **mail id pmwd@bis.gov.in dated 19.04.2023**

Old Case (renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements ✓	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	06 mtr.	06 Mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr. & .75 mtr	1.5 mtr. & 1.10 mtr	MR
	2. Basements	1.25 mtr. & .75 mtr	1.5 mtr. & 1.10 mtr	MR
	C. Protection of exits			
	1. Fire check door	NA	Provided	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	NA	NA	NA
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	20 Nos.	MR
	2) Types	ABC, CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR

✓ 62/60

N/23

6.	First-Aid Hose Reel			
	1) Total number	01	Provided	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors(heat /smoke)	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	D.G set	D.G set	MR
	5) Hooter's Location	Ground	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	NA	Provided at ground & fourth floor	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants floor	01	01	MR
	3) Hose box each floor	01	01	MR
12.	Yard Hydrants/external hydrant			
	1) Total number of hydrants	02	Provided	MR
	2) Hose box	02	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1800 LPM	1800 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	1800 LPM	1800 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 itr.	1,00,000 itr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 itr.	40,000 itr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR

✓ Ld. Se

N/24

	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	Total area location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	NA	NA	NA
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further, shortcomings issued vide letter No.F6/DFS/MS/2021/NDZ/1957 dated 24.09.2021 found complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no F6/DFS/MS/2003/NDZ/2689 dated 31/10/2003, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

A'

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Sh. Ravinder Singh
Designation : ADO (CC)

~~Dy. Chs. Gupta~~

Pl. spk about earliee FSC mentimed at 'A'.

~~12/05/23~~

~~DO (CD) + ADO (CC)~~

- Spoken with DO (CD)
- No part file is attached with main file.

~~12/05/23~~

C.F.O.

~~12/05/2023~~

~~Director~~

~~12/05/23~~

~~DO (CD)~~