

C-25

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/300

Dated: 04/05/2023

FIRE SAFETY CERTIFICATE

Certified that the building of The Fun Valley School Located at RZ-H-921, Gali No. 14, Raj Nagar-II, Palam Colony, New Delhi, having two blocks comprised of Ground Floor & G +01 Upper Floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/165, dated 24/04/2020. The premises was re inspected by the officer concerned of this department on 21/04/2023 in the presence of Mr. Ravi Solanki (Manager). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 04/05/2023 for a period of **three years**, subject to compliance of the condition given below.

Issued on 04/05/2023.. at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, The Fun Valley School Located at RZ-H-921, Gali No. 14, Raj Nagar-II, Palam Colony, New Delhi.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


1. Name & address of the building: The Fun Valley School Located at RZ-H-921, Gali No. 14, Raj Nagar-II, Palam Colony, New Delhi.
2. Type of Occupancy : Educational 02 Blocks(Ground Floor & G +01 U.F)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/165, dated 24/04/20
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 21/04/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Ravi Solanki (Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : Nil, dated 06/04/2023

No. of Students=250
No. of class rooms=20
Plot area=550 sqft
Covered area=400 sqft

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per N/9, N/10 & N/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Direct Accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR (Being old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	Old case	MR (Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	Provided	MR Old Case
	f. Door Size	1 mtr & 1.2 m in new class room	Old case	MR (Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



Fire Extinguishers				
<ul style="list-style-type: none"> Total numbers Types IS marking 	01 ABC & CO ₂ for every 300 sq.mtr ISI marked	4 Nos.	MR	
		Provided	MR	
		ISI marked	MR	
5. First - Aid Hose Reels				
<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
7. Automatic fire detection and alarming system				
<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
8. MOEFA	NA	NA	NA	
9. Public Address System	NA	NA	NA	
10. Automatic Sprinkler System				
<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
11. Internal Hydrants:				
<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
12. Yard Hydrants				
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA	
	NA	NA	NA	
13. Pumping Arrangements				
<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	



14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2020/SZ/165, dated 24/04/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
25/4/23

Uday Vnr Singh
ASD/POK

DO/SW
26/4/23

CFO/(S2)
26/4/2023

Director

[Handwritten Signature]