



C-32

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/2023/235

Dated: 19/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Yashwant Place service Station Retail outlet(Petrol & Diesel) at Africa Avenue, Chanakyapuri, New Delhi-110021 comprised of Ground + One upper Floor only owned / occupied by M/s Yashwant palace service Station, was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/Petl/2020/SZ/132 dated 05/03/2020. The premises was re-inspected by the officer concerned of Fire Service on 12.05.2023 in the presence of Miss Rajni (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Hazardous (Group-J) with effect from 19/5/2023 for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/5/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR

Copy to :-

1. M/s Yashwant palace service Station Retail outlet(Petrol & Diesel) at Africa Avenue, Chanakyapuri, New Delhi-110021.
2. MOH, Health Department, NDMC, Palika Kendra, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW dfs Delhigovt nic in.

INSPECTION REPORT

1. Name & address of the building: **M/s Yashwant Palace Service Station Retail outlet (Petrol & Diesel) at Africa Avenue, Chanakyapuri, New Delhi-110021.**
2. Building Comprised of : **Ground + One upper only**
3. Type of Occupancy : **Hazardous Building (Group-J)**
4. Type of Case : **Renewal**
5. Details of previous NOC : **F.6/DFS/MS/Petl./2020/SZ/132 dated 05/03/2020**
6. Fire Safety directives Letter No.: **F.5/(12)/DFS/BP/2003/354 dated 12/05/2003**
7. Date of inspection : **12/05/2023**
8. Name of the Inspecting Officer : **Santosh Kumar A.D.O. (S.J.)**
9. Name and designation of Officer
From the building side : **Miss RAJNI (Manager)**
10. Year of construction : **2003**
11. Applicant's letter revived through email Dated **26/04/2023**

S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09mtr.	09mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 nos	01 nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.10m	1.10m	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	18 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

N-15


6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A

41-66

15	Exit Signage	Required	Displayed in Hindi & English	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided (50KVA)	MR
18	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any;	Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen in premises.		MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Petl/2020/SZ/132 dated 05/03/2020 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 15.05.23
 Signature of the Inspecting Officer
 Name : Santosh Kumar
 Designation : A.D.O. (S.J.)


DO/South leave

CFO Mugh
15/5/2023

Director Mugh
15/05/23

Director Mugh
19/05/23

F.T. letter is put up for sig. Pl.


 15/05/23