

329



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/WZ/COS/2023/EH/164

Dated: 26/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Burger King India Private Limited, located at Shop No.-10, DMRC Metro Station, Kirti Nagar, New Delhi-110015, in a building comprised of Ground floor only, owned/occupied by M/s. Burger King India Private Limited, was issued Fire safety Certificate vide Letter No. F6/DFS/MS/EH/2020/38 dated 07/02/2020, The premises was re-inspected by officer concerned of this department on 09/05/2023 in the presence of Sh. Akshay (Manager) and found that the said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & the said premises is fit for occupancy class "Assembly" Group - D(Eating House) with effect from 26/05/2023 for a period of three year in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 condition mentioned below.

Issued on.....26/05/2023.....at New Delhi by.


Atul Garg
Director

Copy to:

1. The Owner/occupier Burger King India Private Limited, located at Shop No.-10, DMRC Metro Station, Kirti Nagar, New Delhi-110015.
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest_zone@gmail.com)


24/5/2023

INSPECTION REPORT

1. Name & address of the building : M/s. Burger King India Private Limited. Located at Shop No.-10, DMRC Metro Station, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy : Assembly (Restaurant/Eating House)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2020/38 dated 07/02/2020
5. Fire Safety directives letter No : Nil
6. Date of inspection : 09/05/2023
7. Name of the Inspecting Officer: Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Akshay (Manager)
9. Year of Construction : 2011 (As per MHA Portal)
10. Applicant's letter No. : 2021040412117 dated 26/04/2023
11. M/s Burger King India Pvt. Ltd. is at ground floor in a P.D area of DMRC Metro Station, Kirti Nagar New Delhi - 110015, in a building comprised of Ground floor only. ✓

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	30 m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.35 mtr X 1,	1 X 1.65 mtr, 1 X 2.40 mtr	MR
	g. Door Size	2 mtr. X 1		
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	02 nos.	04 Provided	MR
	• Types	DCP & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

(Signature)

(Signature)

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 Required	Common with the Metro Station	MR
	• Length of hose reel hose	30 m	Common with the Metro Station	MR
	• Nozzle diameter	5 mm	Common with the Metro Station	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	Common with the Metro Station		
	• Size of riser/down-comer	150 mm	Common with the Metro Station	MR
	• Number of hydrants per floor	Required	Common with the Metro Station	MR
	• Hose Box	Required	Common with the Metro Station	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Common with the Metro Station	MR
	➤ Head of the pump	40 m	Common with the Metro Station	MR
	➤ Power Supply	Required	Common with the Metro Station	MR
	➤ Auto Starting of pump	Required	Common with the Metro Station	MR
14	Captive Water Storage for fire fighting. Common with the mall			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20,000 ltrs	Common with the Metro Station	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire fighting arrangements provided in the building/restaurant were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/EH/2020/38 dated 07/02/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

02/ADO/MN
17/5/2023

~~DO (West)~~

~~Signature~~
17/5/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~Signature~~
18/5/2023

~~Signature~~
19/5/2023

~~Signature~~
22/5/23

~~Signature~~ Sir, F.T is put up for your
Kind personal & signature please.

~~Signature~~
24/5/2023

DO (WEST)/S/G
DATED 18/05/2023