

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 261

Dated: 29/05/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Foot ball house (All India Football Federation) located at sector-19, Dwarka New Delhi, comprised of Basement + Ground +03 upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2006/471 dated 24/02/2006. The premise was re inspected by the officer concerned of this department on 18/05/2023 in the presence of. Col. BMR Mehta (Retd.) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A-4 with effect from 29/05/2023 for a period of five years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...29/05/2023... at New Delhi by.


(Anil Garg)
Director
Delhi Fire Service.

Copy to:

1. The President, Foot ball house for All India Football Federation sector-19, Dwarka New Delhi,.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/11
INSPECTION REPORT



1. Name & address of the building: Football house (All India Football Federation) Located at sector-19, Dwarka New Delhi,
2. Type of Occupancy : *Business*
3. Type of Case : Renewal (B+G+3UF)
4. Details of previous NOC: F6/DFS/MS/2006/471 dated 24/02/2006
5. Fire Safety directives L. No. : F6/DFS/MS/2004/876 dated 19/04/2004
6. Date of inspection : 18/05/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Col. BMR Mehta (Retd.)
9. Year of Construction : 2004
10. Applicant's letter No. : AIFF/ADMIN/FIRE/2023/78, dated-09/05/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC & As per N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	5 mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	2 Provided	MR
	• Basements	2 Nos	2 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m	117 cm & 142cm	MR Old Case
	• Basements	1.5 m	162 cm & 156cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	01 mtr & 1.5m	Old case	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	1 hrs rating	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NR	NR	NR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC, WCO2 & CO2	ABC	MR
	• IS marking	ISI marked	ISI marked	MR

h *g* *a*

N/12

6.	First - Aid Hose Reels			
	• Total numbers on each floor	01 nos	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 m	05 m	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	GF	GF	MR
	• Location of Repeater Panel	Required	GF	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Appropriate place	Near Staircase	MR ✓
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR ✓
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR ✓
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements:			
	• Ground Level	1620 lpm	Provided	MR
	• Discharge of main pump	70 m	Provided	MR
	➤ Head of main pump	01 Nos.	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	70 m	Provided	MR
	➤ Jockey pump head	1620 lpm	Provided	MR
	➤ Standby Pump out put	70 mtr	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	900 lpm	Provided	MR
	• Terrace level	35 mtr	Provided	MR
	➤ Discharge of pump	Required	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump			
14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	At ground level	50,000 ltr	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	Provided	MR
		Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts	Required	Provided	MR
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	DG Set	MR
17	Standby power supply	Required	DG Set	MR

18	Refuge Area	NA	NA	NA
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire control room	NA	NA	NA
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/2006/471 dated 24/02/2006 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
 Signature of the Inspecting Officer
 Name :- Udaivir Singh
 Designation ADO/DWK

[Signature]
 DO/SO
 19/5/23

[Signature]
 CFO (S2)
 19/5/2023

[Signature]
 Director
 19/5/23

[Signature]
 Any/wh

Fire Pt letter is not up for sig pte

[Signature]
 DIRECTOR
 19/5/23
 M

[Signature]
 22/5/23