

C-76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/ 375

Dated: 31/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Veda Vyasa D.A.V. Public School, Vikas Puri, New Delhi-110018, comprised of four blocks namely Senior Students Block No.-1 (SSB-1) having ground plus four upper floors, Senior Students Block No.-2 (SSB-2), Administrative Block (AB) & Primary Students Block (PSB) each block having ground plus three upper floors. All blocks are interconnected at each floor level, owned/occupied by Veda Vyasa D.A.V. Public School was issued FSC by this department vide letter No. F.6/DFS/MS/School/2015/SZ/1558 dated 28.08.2015. The School building was re-inspected by the officer concerned of this department on 18/05/2023 in the presence of Sh. Rajender Singh Dogra (Admin.) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 31/05/2023 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
gag.

Copy to:-

1. The Principal, Veda Vyasa D.A.V. Public School, Vikas Puri, New Delhi-110018.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhi.govt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/25

INSPECTION REPORT

1. Name & address of the building : Veda Vyasa D.A.V. Public School, Vikas Puri, New Delhi-110018
2. Building comprised of : Four blocks, Block No.1 having G+4 upper floors & Block No. 2, 3 & 4 having G+3 upper floors, all blocks are interconnected at each floor level.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2015/SZ/1558 dated 28.08.2015
6. Fire Safety directives letter No : N/A
7. Date of inspection : 18/05/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Rajender Singh Dogra (Admin.)
10. Year of Construction : 1992, 1998 & 2000
11. Applicant's letter No : VVDAV/VP/23/67 dated 10/05/2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (06 m) 4.5 m NA	Provided 05 m NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	04 No's NA	Provided NA	M/R NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m NA	1.54, 1.52, 1.55 & 1.96 m NA	M/R ✓ NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Provided	MR
	f. Class room Door Size	1.50 m	2.55 & 2.35 m	M/R
		1.0 m	1.10 & 1.23 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A NA N/A N/A	N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA Required	NA Natural ventilation	NA M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	30 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

12

N/26

Standby power

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Three	Provided	M/R
		30 m	Provided	M/R
		5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	NA	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		900 LPM	900, 450 & 180 LPM Provided	MR
		30 m	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		20,000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		Required	Provided	M/R

k

w

N/27

Standby power supply	N/A	N/A	N/A
Refuge Area.			
➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

Previously Fire Safety Certificates was issued vide letter No. F.6/DFS/MS/School/2011/SZ/1583 dated 15/07/2011 & F.6/DFS/MS/School/2015/SZ/1558 dated 28.08.2015 for the same building.

Note :-As per the structure stability certificate placed at C-54 total height of the said building is 14.63 Mtr. Approx.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No.F.6/DFS/MS/School/2023/SZ/194 dated 18/04/2023 has been rectified.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/1558 dated 28.08.2015 renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. Keel
22/5/2023

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

D.O (South-West)
[Signature]
23/07/23
CfO (S2)
[Signature]
24/5/2023
~~Director / *[Signature]*~~
29/05/23

Amey R. Ryan / 22/0