

2/11

C-34

FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI

No. F6/DFS/MS/SZ/2023/School/368

Dated: 29/05/2023

FIRE SAFETY CERTIFICATE


Certified that the building of Govt. Co-Ed Senior Secondary School Located at Mahavir Enclave, New Delhi - 110045, comprised of Ground + Upper Floor, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/266, dated 10/08/2020. The premises was re inspected by the officer concerned of this department on 19/05/2023 in the presence of Ms. Santara Kumari (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DDI Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B "Educational building" with effect from 29/05/2023 for a period of three years, subject to compliance of the conditions printed as under:

Issued on 29/05/2023 at New Delhi by:


 Director
 Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. The Principal, Govt. Co-Ed Senior Secondary School at Mahavir Enclave, New Delhi 110045.


 26/5/23

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations wrt construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Govt. Co- Ed Senior Secondary School
Located at Mahavir Enclave, New Delhi - 110045.
2. Type of Occupancy: Educational G + 1 Upper Floors only
3. Type of Case: Renewal
4. Details of previous NOC: F.6/DFS/MS/School/2020/SZ/266, dated 10/08/2020
5. Fire Safety directives Letter No.: Circular No 3298-3398 Dated 01/03/2011
6. Date of inspection: 19/05/2023
7. Name of the Inspecting Officer: Udai vir singh ADO (DWK)
8. Name and designation of Officer
from the building side: Ms. Santara Kumari (Principal)
9. Year of Construction: Before 2010
10. Applicant's letter No.: Email Dated - 04/05/2023

No. of Students= 840
No. of class rooms= 15+7.
Plot area= 2869 sqmtr
Covered area= 1749 sqmtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10, N/11 & N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr additional staircase of 75 cm if less than 150 cm	2x142cm	MR (Being old case) ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	160cm	MR
	f. Door Size	01 mtr	Old Case	MR (Being old case) ✓
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation provided	MR ✓

(Handwritten signature)

21/14

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	17 nos. ABC or CO ₂ ISI marked	22 Provided	MR ✓
			Provided	MR
			ISI marked	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required	Provided	MR ✓

Handwritten signature/initials at the bottom of the page.

N/15

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any.		ABC Fire Extinguisher Near Electric	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F-6/D/S/MS/School/2020/S//266, dated 10/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

[Handwritten signature]
22/5/22

Signature of the Inspecting Officer
Name *Uday Verma*
Designation *ADDO/MS*

[Handwritten signature]
22/5/22

[Handwritten signature]
22/5/2022

[Handwritten signature]
22/5/22

[Handwritten signature]