

C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2023/100

Dated :- 02/06/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Lord Krishna Palace Guest House located at 2304-06, Laxmi Narayan Street, Chuna Mandi, Pahar Ganj, New Delhi comprised of Basement + Stilt + Ground + 03 Upper floors, Basement (Storage), stilt (parking), Ground floor to 3rd floor (07 guest rooms at each floor), total 28 guest rooms up to third floor only. The FSC was earlier granted by this department vide letter No. F6/DFS/MS/GH/NDZ/2020/93 dated 13.03.2020 for 28 guest rooms up to third floor only, Now, the premises was re-inspected by the officer concerned of this department on 23/05/23 in the presence of Sh. Manish Arora (Owner) and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, (Sub Division-A-1) Basement (Storage), stilt (parking), Ground floor to 3rd floor (07 guest rooms at each floor), total 28 guest rooms up to third floor only, and valid up to 31.03.2026 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 02/6/2023 at New Delhi by

(Atul Gupta)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi, to kindly ensure the occupancy as detailed above and deviation if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online ID No. online id no.2023051709106 dated 18/05/2023
3. Sh. Manish Gupta, M/s Lord Krishna Palace Guest House, 2304, 2305, 2306, Laxmi Narayan Street, Chuna Mandi, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Stilt floor shall be used strictly for parking only.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.
10. The basement shall be used strictly as per BBI, concerned.

INSPECTION REPORT

1. Name & address of the building:- M/s Lord Krishna Palace Guest House at 2304/2305/2306, Laxmi Naryan Street, Chuna Mandi, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
B + Stilt + Ground + 03 Upper floors (total 28 Guest rooms)
Basement (Storage), Stilt floor (Parking), Ground Floor to 3rd floor (07 guest rooms at each floor) renewal
3. Type of case:-
4. Details of previous FSC:- F6/DFS/MS/GH/NDZ/2020/93 dated 13 03 2020
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/05/23
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh, ADO
8. Name & designation of officer From the building side:- Sh. Manish Arora (Owner)
9. Year of construction:- 2015
10. Applicant's letter No.- online id no. 2023051709106 dated 18.05.2023

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per previous FSC	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
B. Width of staircase				
	1. Upper floors	1.5 mtr. & 1.35 mtr.	1.5 mtr. & 1.35 mtr.	MR
	2. Basements	1.5 mtr. & 1.35 mtr.	1.5 mtr. & 1.35 mtr.	MR
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.2 mtr.	1.2 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	12 ACPH	Provided	MR
	2) Upper floors	12 a/c per hour	Natural	MR
5. Fire Extinguishers				

✓ 6/50

N16

	1) Total numbers	20 Nos.	20 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors (CO)	Required	Provided	MR
	2) Location of main panel	At ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	At each floor	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	Required	Provided	MR
	3) Hose box	Required	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

✓ W, 50,

N/E

	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The original file is not teachable at MS cell, accordingly, the fire protection systems provided in the guest house building as per previous FSC inspection report, were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules 35(6), if approved, we may renew the FSC issued vide letter no F6/DFS/MS/GH/NDZ/2020/93 dated 13.03.2020, up to third floor only, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal/approval and signature please.

Signature of inspecting officer

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

Sh:- Ravinder Singh
Designation :ADO/CC

~~Dy.fo (NDZ)~~

26/5/23

~~C.fo.~~

30/5/2023

~~Director~~

21/5/23

FT

put up out #
copy

20/4/23

21/5/23