



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2023/NDZ/387

Dated: 05/06/2023

FIRE SAFETY CERTIFICATE

Certified that MCD Pratibha Co-Ed School at A-Block, Dilshad Garden, Delhi-110095, comprised of ground plus one upper floor owned/occupied by MCD Pratibha Co-Ed School was issued FSC vide letter No. F.6/DFS/MS/School/2020/NDZ/181 dated 11/05/2020. The premises was re-inspected by the officer concerned of this department on dated 25/05/2023 in the presence of Mrs. Hemlata Yadav, Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 05/06/2023, for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 05/06/2023..... at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

To:-

1. The Principal
MCD Pratibha Co-Ed School at A-Block, Dilshad Garden, Delhi-110095
2. The Director of Education, MCD
5th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

M/13

INSPECTION REPORT

- 1 Name & address of the building MCD Pratibha Co. Ed. School
A-Block, Dilshad Garden, Delhi 95
- 2 Building is comprised of Ground plus first floors only
- 3 Type of Occupancy Educational
- 4 Type of Case Renewal
- 5 Details of Previous NOC letter F 6/DFS/MS/School/2020/NDZ/181 dt 11.3.2020
- 6 Fire Safety direction letter No. F 16 Estate/CC Fire safety 2011/3298 to 3398 dated 01/03/2011
- 7 Date of Inspection 25/05/2020 25/05/2023
- 8 Name of the Inspecting officers ADO Deepak Kumar
- 9 Name and designation of Officer from the building side Mrs. Hemlata Yadav, Principal
- 10 Year of Construction 2009
- 11 Applicant's letter No. Letter No. Nil, Dated- 058/05/2023

Sr No	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Circular dated 01/03/2011	Provided at Site	Remarks
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr N/A N/A 	<ul style="list-style-type: none"> 09 mtr N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 01 nos N/A 	<ul style="list-style-type: none"> 02 nos N/A 	<ul style="list-style-type: none"> N/A N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 1.50m N/A 	<ul style="list-style-type: none"> 2.40 mtr & 2.40 mtr N/A 	<ul style="list-style-type: none"> N/A N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	d. No. of Continuous Staircases to Terrace	01 nos	01 nos	N/A
	e. Width of Corridor	1.50m	1.50m	N/A
	f. Door Size	01m	1.20m	N/A
03	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A
04	Smoke Management System			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
05	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 04 nos ABC/CO₂ ISI marked 	<ul style="list-style-type: none"> 10 nos ABC/CO₂ ISI marked 	<ul style="list-style-type: none"> N/A N/A N/A

2 A 50

2/1/14

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose			
	• Nozzle diameter	N/A	N/A	N/A
		N/A		N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

2 P 100

N/15

16	Provision of Lifts,			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2020/NDZ/181 dated 11/05/2020 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak Kumar
25/05/2023
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

~~DO(FD)~~
Abhishek
26/05/2023
By: CFO/(N32) *Deep*
30/05/23
C.F.O. *Deep*
30/05/2023
Directed by *Deep*
31/5/22
Deep