



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2023/NDZ/385

Dated 05/06/2023

FIRE SAFETY CERTIFICATE

Certified that S. R. Public School running at ground and first floor building comprised of ground, first and second floor at A-140 Part No. 03 School Line Sonia Vihar Delhi-110094, owned/occupied by S. R. Public School was issued FSC vide letter No F.6/DFS/MS/School/2016/1851 dated 29/12/16. The premises was re-inspected by the officer concerned of this department on dated 23/05/2022 in the presence of Mr. Attar Singh (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 05/06/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 05/06/2023 at New Delhi by


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

To:-

1. The Principal
S. R. Public School at A-140 Part No. 03 School Line Sonia Vihar Delhi-110094
2. The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 25/05/2023 that he will not use second floor for school purpose falling which this FSC should be treated null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc may be got verified from the concerned authorities
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/A

- 1 Name & address of the building S R Public School
A-140 part No. 03 School Line Sonia Vihar Delhi-94
- 2 Building is comprised of Ground plus two upper floors
(School is running on ground & first floor only)
- 3 Type of Occupancy Educational
- 4 Type of Case Renewal
- 5 Details of Previous FSC letter F 6/DFS/MS/School/2016/1851 dt 29/12/16
- 6 Fire Safety directive letter No F 16/Estate/CC/Fire Safety/2011/3298 to 3393
dated 01/03/11 issued by DoE
- 7 Date of Inspection 23/05/2022
- 8 Name of the Inspecting officers ADO Deepak Kumar
- 9 Name and designation of officer from the building side Mr. Attar Singh (Manager)
- 10 Year of Construction 2004
- 11 Applicant's letter No S R P Dated- 25/04/2023

Sr No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/MP
01	Access to Building			
	• Road width	06 mtr	06 mtr ✓	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a Number of Staircases			
	• Upper floor	01 nos	02 nos ✓	MR
	• Basement	N/A	N/A	N/A
	b Width of Staircases			
	• Upper floor	1.50 mtr	1.20 mtr each ✓	MR
	• Basement	N/A	N/A	N/A
	c Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d No. of Continuous Staircases to Terrace	01 no	01 no ✓	N/A
	e Width of corridor	1.50 mtr	1.30 mtr	MR
	f Door Size	01 mtr	1.12 mtr ✓	MR
03	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers			
	• Total numbers	04 nos	06 nos ✓	
	• types	ABC /CO ₂	ABC /CO ₂	
	• IS marking	ISI marked	ISI marked	

2. 50/

06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage			
		N/A	N/A	N/A

16	Provision of Lifts			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any	N/A	N/A	N/A

Note:- Building is ground, first and second floor only but applicant has submitted an undertaking dated 25/05/2023 placed at C-29 that he will not use second floor for school purpose.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No F 6/DFS/MS/School/2016/1851 dated 29/12/16 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Signature of the Inspecting Officer
Name - Deepak Kumar
Designation - A D O (Shd)

DO (ED)

Dy. C.F.O. 26/05/2023
LTP 26/05/23

C.F.O. 30/5/2023
Director 31/5/23

ADP/SHD

Sir, F.T. letter is put up for your kind signature pl. 25/05/23