

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2023/SZ/367

Dated 29/05/2023

FIRE SAFETY CERTIFICATE

Certified that the **Shri Yogmaya Mandir Primary School** located at Mehrauli, New Delhi 110030 comprised of Ground floor only owned/ occupied by Shri Yogmaya Mandir, Primary School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/1243 Dated 11-06-2019. The said premise was re-inspected by officer concerned of this department on 23/05/2023 in presence of Mrs. Richa Sharma (In-charge) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 29/05/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 29/05/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. HOS, Shri Yogmaya Mandir Primary School located at Mehrauli, New Delhi 110030
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

| | | | | |
|--------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|--------------------------------------|--------------------------------------|
| 1 | Name & Address of the Building | Shri Yogmaya Mandir, Primary School located at Mehrauli, New Delhi 110030 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | Ground floors | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/School/2019/SZ/1247 Dated 11-06-2019 | | |
| 6 | Fire Safety Directives Letter No | DOE Circular dated 01/03/2011 | | |
| 7 | Date of Inspection | 23/05/2023 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mrs. Richa Sharma (In-charge) | | |
| 10 | Year of construction | 1965 | | |
| 11 | Applicant letter No | Outdoor diary no 1611 dated 02/05/2023 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/NMR |
| 1. | Access to Building. | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 6 mtr -NA- -NA- | 2.50 mtr -NA- -NA- | MR (old case) -NA- -NA- |
| 2. | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors | -NA- | -NA- | -NA- |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | -NA- | -NA- | -NA- |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e) Width of corridor | -NA- | -NA- | -NA- |
| | f) Door size | 1m | Provided | MR |
| 3. | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- |
| 4. | Smoke Management system. | | | |
| | <ul style="list-style-type: none"> Basement Upper floors | 30 ACPH 12 ACPH | -NA- NA | -NA- NA |
| 5. | Fire Extinguishers. | | | |
| | <ul style="list-style-type: none"> Total numbers Types ISI Marking | Required ABC / CO2 ISI marked | 03 Nos ABC & CO2 Provided | MR MR MR |
| 6. | First Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose-reel hose Nozzle Diameter | -NA- -NA- -NA- | -NA- -NA- -NA- | -NA- -NA- -NA- |
| 7. | Automatic fire detection & alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors | -NA- | -NA- | -NA- |

(Handwritten mark)

(Handwritten mark)

| | | | | |
|-----|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|----------|------|
| | <ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box | NA | -NA- | NA |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose box | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey Pump output Jockey Pump head Standby Pump output Standby Pump head Auto Starting/Manual Stopping Pump house access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump Power supply Auto starting of pump | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 14. | Captive water storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire Service Inlet Access to tank. Overhead tank capacity | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Fireman's switch Lift signage | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17. | Standby Power Supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | <ul style="list-style-type: none"> Detector system panel Flow switch panel | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

Handwritten signature

Handwritten mark

NA-
NA-
NA-

2019/11/24 11:51:20

| | | | |
|-----------------------|------|------|------|
| • PA system panel | -NA- | -NA- | -NA- |
| • Battery backup | -NA- | -NA- | -NA- |
| • Building floor plan | -NA- | -NA- | -NA- |

20. Special Fire Protection System for the Protection of special Risk, if any. -NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/DFS/MS/School/2019/SZ/1247 Dated 11-06-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

Sh
24/5/2023

Signature of the Inspecting Officer
Name Sh Rajesh Kumar
Design ADO (BCP)

DO (SD)

Muse
24/5

of
24/5/2023

Director
25/5/23

ADP/BJ

As approved, F.T. letter is put up for your signature pl

Director
25/5/23
n

Sh
26/5