



No. F6/DFS/MS/School/WZ/2023/ 383

Dated - 01/06/2023

FIRE SAFETY CERTIFICATE

Certified that the St. Samuel Model School Located at E-2/14, 15, 17 & 17A, Budh Vihar, Ph-1, Delhi-110086, comprised of Ground + 01 Upper Floor was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2020/258 Dated 04.08.2020. The said premise was re-inspected by the officer concerned of this department on 20.05.2023 in the presence of Sh. Vikas (Manager) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 01/06/2023 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 01/06/2023 at New Delhi by


(Arul Garg)
Director
Delhi Fire Service
21/5/23

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, St. Samuel Model School, E-2/14, 15, 17 & 17A, Budh Vihar, Ph-1, Delhi-110086.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

- 1 Name and address of the building: **St. Samuel Model School Located at E-2/14,15,16,17A, Budh Vihar, Ph-1, Delhi-110086.**
- 2 Type of Occupancy Educational (Single block-G + 01 Upper Floor only)
- 3 Type of Case Renewal
- 4 Details of previous NOC : 16/DI S/MS/2020/258 Dated 04.08.2020
- 5 Fire Safety directives Letter No : D O E Circular no 3298-3398 dated 01-03-2011
- 6 Date of inspection : 20.05.2023
- 7 Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
- 8 Name and designation of Officer
from the building side : Sh Vikas (Manager)
- 9 Year of Construction : 2006 & Addition/Alteration 2013
- 10 Applicant's letter No. : email dated 19.05.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D O E Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 04.08.2020	Provided at site	Remarks MR/NMR
1	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	1.6 m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 m	1.08 m	MR
3	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	06 nos	08 nos	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOLFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

Dr

X

19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2020/258 Dated 04.08.2020 is recommended.

Accordingly DFA is put up for approval please.

Q11461
22/5/23
Aman Kumar Lathar
ADO (JWP)

DO/W

22/5

29/5/2023

Director
29/5/23

AD/SWP

Sir, F.S. letter is put-up for your signature p...

Director
1/06/23

Q11461
31/5/23
Aman (JWP)

Aslan