





No. F6/DFS/MS/School/WZ/2023/381

Dated:- 01/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School (School ID-1413069), Located at Avantika, Sector-1, Rohini, Delhi-110085 comprised of Ground + 03 Upper Floors owned/ occupied by Govt. Girls Sr. Sec. School (School ID-1413069) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 20.05.2023 in the presence of Sh. Anil Kumar Gupta (Proprietor, Repair Associates) and that the building/premises is fit for occupancy class " Educational Building" Group B with effect from 01/06/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/06/2023... at New Delhi by.


(Atul Garg)
Director

31/5/23

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054
2. The Assistant Engineer (E), PWD Sub Division - 2, Ed. Elect. Edn. 1 Div. (N), Sector - 16, Rohini, Delhi-110089.
3. The Principal, Govt. Girls Sr. Sec. School (School ID-1413069), Avantika, Sector-1, Rohini, Delhi-110085

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : **Govt. Girls Sr. Sec. School (School ID-1413069) Located at Avantika Sector-1, Rohini, Delhi-110085.**
2. Type of Occupancy : Educational,
3. Type of Case : New Block, (G + 03 Upper Floors)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : as per NBC Part-IV
6. Date of inspection : 20.05 2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Anil Kumar Gupta (Proprietor, Repair Associates)
9. Year of Construction : 2021-22
10. Applicant's letter No. : email dated 03.10.2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|------|---|---|--|----------------|
| 1 | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | 06 m 4.5 m NA | Provided Provided NA | MR MR NA |
| 2 | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | 04 | 04 & 01 ramp | MR |
| | <ul style="list-style-type: none"> • Upper floors • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | 1.5 m each | 1.71 m x 1, 1.69 m x 3 & 1.66 m to 1.89 m x 1 ramp | MR |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 04 | Provided | MR |
| | e. Width Of Corridor | 1.5 m | Provided | MR |
| | f. Door Size | 1.2 m | Provided | MR |
| 3 | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 4 | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | NA | NA | NA |
| | | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 24 nos ABC & CO ₂ ISI marked | 138 nos Provided Provided | MR MR MR |

| | | | | |
|----|---|------------|-------------|----|
| 6 | First - Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 03 | 05 | MR |
| | | 30m | Provided | MR |
| | | 5mm | Provided | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System | NA | NA | NA |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants: | | | |
| | <ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12 | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13 | Pumping Arrangements: | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 450 lpm | 450 lpm x 2 | MR |
| | | 40Mtr | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14 | Captive water Storage for fire fighting: | | | |
| | <ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 10,000Ltrs | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | NA | NA | NA |
| | | NA | NA | NA |
| 19 | Fire control room | | | |
| | <ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |

fr

Q

| | | | |
|--|----------|---|----|
| 20. Special Fire Protection Systems for Protection of special Risks, if any; | Required | ABC type fire ext. for electrical panel | MR |
|--|----------|---|----|

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.


 Aman Kumar Lathar
 ADO (JWP)

~~DO/W~~

~~by 24/5~~


~~CFO 29/5/2023~~

~~Director 29/5/23~~

~~Amo/pwt~~

Sir,
 R.S. letter is put-up for your signature M.

~~Director~~
 full


 31/5/21
 Amk (JWP)