




No. F6/DFS/MS/School/WZ/2023/ 380

Dated:- 01/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070), Located at Sector-16, Pocket-A, Rohini, Delhi-110085, comprised of Ground + 03 Upper Floors, except M.P. Hall owned/ occupied by Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 20.05.2023 in the presence of Sh. Anil Kumar Gupta (Proprietor, Repair Associate) and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 01/06/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/06/2023 at New Delhi by


(Atul Garg)
Director

Qe ac
31/5/23

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054
2. The Assistant Engineer (E), PWD Sub Division - 2, Ed. Elect. Edn. I Div (N), Sector - 16, Rohini, Delhi-110089.
3. The Principal, Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070), Sector-16, Pocket-A, Rohini, Delhi-110085

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070)** Located at **Sector-16, Pocket-A, Rohini, Delhi-85.**
2. Type of Occupancy : Educational,
3. Type of Case : New Block, (G + 03 Upper Floor, except M.P. Hall)
NEW CASE
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : as per NBC Part-IV
6. Date of inspection : 20.05.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Anil Kumar Gupta, (Proprietor, Repair Associate)
9. Year of Construction : 2021-22
10. Applicant's letter No. : email dated 23.03.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04 & 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	1.73 m x 3, 1.62 m x 1 & 1.60 m to 1.80 m x 1 ramp	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04	04	MR
	e. Width Of Corridor	1.5 mtrs	Provided	MR
	f. Door Size	1.2 mtrs	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	24 nos	142 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

20. Special Fire Protection Systems for Protection of special Risks, if any,	Required	ABC type fire ext for electrical panel	MR
--	----------	--	----

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

Amitha
29/5/23

Aman Kumar Lathar
ADO (JWP)

~~20/5/23~~

~~24/5~~

~~29/5/2023~~

~~Director~~
~~29/5/23~~

F/M

~~29/5/23~~

Sir, F.S. letter is put-up for your signature pl.

~~Director~~
~~11/06/23~~

Amitha
21/5/23
Aman (JWP)

M