



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No F 6 DFS/MS/School/2023/SZ/392

Dated 06/06/2023

FIRE SAFETY CERTIFICATE

Certified that **Ryan International School** located at Sector-C, Pocket-8, Vasant Kunj, New Delhi 110070 comprised of Ground plus three upper floor owned/ occupied by Ryan International Group of Institutions, India was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/208 Dated 01/07/2020. The said premise was re-inspected by officer concerned of this department on 28/05/2023 in presence of Mr. Joseph Rodrigues (Admin) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational Building Group – B" with effect from 06/06/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 06/06/2023 at New Delhi by


(AJUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to -

1. The Principal, Ryan International School at Sector-C, Pocket-8, Vasant Kunj, New Delhi 110070
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system
3. This certificate cannot be treated as regularization of unauthorized construction, if any
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2 8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1 4 3 of UBBL-2016), if any
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry "

INSPECTION REPORT

1	Name & Address of the Building	Ryan International School, Sector-C, Pocket-8, Vasant Kunj, New Delhi-110070		
2	Type of Occupancy	Educational Building. "Group-B" (School)		
3	Building Comprised of	Ground plus three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F 6/DFS/MS/School/2020/SZ/208 Dt 01/07/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	28/05/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Joseph Rodrigues (Admin)		
10	Year of construction	1994		
11	Applicant letter No	Outdoor diary no 187 dated 10/04/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR ✓
	• Gate width	Required	4.5, 3.60 & 3.53 mtr	MR ✓
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	Required	06 Nos	MR ✓
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	Required	1.50m, 1.46m, 1.30m, 1.47m, 1.50m & 1.50m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	05 Nos	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.0mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	32 No's	40 No's	MR
	• Types	ABC / CO ₂	ABC-26 & CO ₂ -11	MR ✓
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor	3 No's	4 No's	MR
	• Length of hose-reel hose	30m	30m	MR ✓
	• Nozzle Diameter	5mm	5mm	MR

RYAN INTERNATIONAL SCHOOL, SECTOR-C, POCKET-8, VASANT KUNJ, NEW DELHI-110070

2/18

7	Automatic fire detection & alarming system. <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants. <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box 	-NA-	100 mm	-NA-
		-NA-	4 Nos	-NA-
		-NA-	4 Nos	-NA-
12.	Yard Hydrants. <ul style="list-style-type: none"> Total number of hydrants Hose box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements. <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey Pump output Jockey Pump head Standby Pump output Standby Pump head Auto Starting/Manual Stopping Pump house access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump Power supply Auto starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		NA	NA	NA
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	1234 LPM (2 No's)	MR (old case)
		Required	36 mtr each	MR
		Required	Provided	MR
Required	Provided	MR		
14.	Captive water storage for fire fighting. <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire Service Inlet Access to tank Overhead tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		10,000 Ltr	40,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. <ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Fireman's switch Lift signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area <ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.	-NA-	-NA-	-NA-


M W

	• Detector system panel	-NA-	-NA-	-NA-
	• Flow switch panel	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular, FSC issued vide letter No F.6/DFS/MS/School/2020/SZ/208 Dt.01/07/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Designation ADO (BCP)

RYAN INTERNATIONAL SCHOOL, SECTOR-C, POCKET-8, VASANT KUNJ, NEW DELHI-110070

DO (SD)

msk
3/5

cfo Wagh
1/6/2023

Director my
2/06/23

Asy/AD

As approved, F.T. letter is forward for your signature pl

1/6
2/06/2023

Director my
5/06/22

mu