



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001





No. F6/DFS/MS/2023/School/ 401

Dated: 09/06/2023

FIRE SAFETY CERTIFICATE

Certified that the **Dayanand Public School** located at **Arya Samaj Model Town-III, Delhi-110009** comprised of **Ground & 03 upper floors only** owned/occupied by **Dayanand Public School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2020/239** dated **20.07.2020**. The premises was re-inspected by the officer concerned of this department on **25.05.2023** in presence of **Smt. Vani Malik (Vice-Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class '**Group B Educational**' with effect from **09/06/2023**.... for a period of **Valid up to 31.03.2026** subject to compliance of the conditions mentioned below:

Issued on **09/06/2023**..... at New Delhi


 (Atul Garg)
 Director
 Ph:-011-23414000


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Dayanand Public School located at Arya Samaj Model Town-III, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

- 1 Name & address of the building : Dayanand Public School at Arya Samaj, Model Town-III, Delhi-110009
- 2 Type of Occupancy : Educational
- 3 Composition of building : Ground & 03 upper floors only
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6/DFS/MS/2020/239 Dated: 20.07.2020
- 6 Fire Safety directives letter No : Nil
- 7 Date of inspection : 25.05.2023
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Mr. Vani Malik (Vice-Principal)
- 10 Year of Construction : 1985
- 11 Applicant's letter No : Letter No. Nil & DFS Dairy No 2127 dated 22.05.2023

Plot Area- 893 m2 approx.

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated: 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR ✓
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m & 0.75m	1.50m & 1.00m	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1.00 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR ✓
5	Fire Extinguishers			
	• Total numbers	12 nos	16 nos	MR
	• Types	ABC/WCo2	ABC-16	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			

f E C

66
A

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02	02no	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	100mm, Provided	NA
		NA	01 at each floor	NA
		NA	01	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	900 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 LTR	10,000 LTR	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	MR

16	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 01.03.2011 the FSC issued vide letter of even no. F6/DFS/MS/2020/239 dated: 20.07.2020 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

D.B. Mukharjee
Divisional Officer (NWD)

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- Asst. Div. Officer (RN)

CFP
2/6/2023

Director
2/06/23

Asst. Div. Officer

As approved, F.C. letter is being sent for your signature Pl.

Copy
for 07/06/2020
above
Cont -